

SECTION 5: Wastewater Sources & Flows

Wastewater Sources	5-1
Hydraulics – Flow Rates	5-16
7080 Versus 7081	5-16
General Hydraulic Considerations	5-16
Estimates of Flow for Dwelling Design	5-18
Measuring Flow for Design and Management.....	5-22
Waste Characteristics: Waste Strength Components	5-31
Biochemical oxygen demands (BOD ₅), Dissolved Oxygen, and Total Suspended Solids (TSS)	5-32
Biological Treatment Processes.....	5-39
Nutrients.....	5-46
Monitoring Wastewater Characteristics	5-62
References	5-64
Appendix 1	5-68
Biological Hazards in Wastewater: FAQs for Septic System Professionals.....	5-68

WASTEWATER SOURCES AND FLOWS

Wastewater Sources

To start this section, it is first important to define these two terms:

1. Wastewater: clear water, stormwater, industrial, sewage (domestic or commercial), or any combination thereof, carried by water.
2. Source: location at which wastewater is generated.

This manual will focus on the sewage constituents of wastewater, but we need to assess the other components to discover if they will interact and affect the onsite sewage treatment system in any way.

Sewage

Definition

Sewage is waste produced by toilets, bathing, laundry, or culinary operations or the floor drains associated with these sources, and includes household cleaners, medications, and other constituents in sewage restricted to amounts normally used for domestic purposes (MN Rules Chapter 7080.1100, Subp. 73). Sewage does not include “clear” water such as swimming pool water, roof drainage, water softener recharge water, or water used to irrigate lawns or gardens.


There are several types or categories of sewage that have been nationally defined by the Consortium of Institutes for Decentralized Wastewater Treatment (CIDWT, 2009):

1. Blackwater: portion of the wastewater stream that originates from toilet fixtures, dishwashers and food preparation sinks.
2. Graywater: Graywater has a number of definitions including water captured from non-food preparation sinks, showers, baths, spa baths, clothes washing machines, and laundry tubs. **Graywater is defined in MN Rules Chapter 7080.1100, Subp. 37 as sewage that does not contain toilet wastes. A Graywater system is one that receives, treats, and disperses only graywater or other similar system as designated by the commissioner (MN Rules Chapter 7080.1100, Subp. 38).** Toilet wastes from the residence or other establishment have to be treated in some other system, or the residence has to have a privy. To prevent hooking up a flush toilet onto a graywater system, the plumbing of the system must have two-inch diameter pipe, rather than four-inch. Even the floor drains have to use two-inch pipe. The exception is for a graywater system being installed for an existing building. There is no need to re-plumb the entire structure. Graywater systems cannot accept garbage disposal waste. Graywater must be fully treated and is further discussed in Section 7.
3. Yellow water: an isolated waste stream consisting of urine collected from specific fixtures and not contaminated by feces or diluted by graywater sources; see also urine separating device.

5-2 ■ SECTION 5: Wastewater Sources and Flows

The amount and type of water discharged to an onsite sewage treatment system is one of the factors used in sizing that system. Other factors that influence sizing include soil properties such as texture, structure, and percolation rate.

FIGURE 5.1 Peak Wastewater Flows from a Single-Family Home



Designing a wastewater treatment system based upon average daily flow would imply that the system is operating beyond its design capacity 50 percent of the time. For this reason, treatment systems are typically designed to produce the required effluent quality when treating the maximum daily flow. This accounts for the natural variability in the amount and strength of wastewater entering a SSTS as shown in Figure 5.1.

The amount of wastewater entering the treatment system is the hydraulic loading rate. In sizing for the hydraulic loading rate, the volume of water flowing through the treatment process is the design parameter under consideration. For the concept of mass loading rate, the idea of the mass or weight of a particular contaminant flowing through the system over

some time is considered. The “organic loading rate,” the number of pounds or kilograms of BOD per day, and the “solids loading rate,” the number of pounds or kilograms of TSS per day, are common mass loading rates.

Water use varies widely among individuals, depending on such factors as background, age and economic status. For example, an individual who was raised in a household without running water will probably be very conservative in water use even when running water is available. Teenagers are typically high water users. The use of hot tubs or water-circulating devices for therapeutic services greatly increases water use.

A number of studies have been made throughout the country on water use habits and rates. In studies made during the 1970s, average water use per person, nationwide, was about 45 gallons per day. A 1999 study found a national water-use rate of about 60 gallons per person per day with a variation of plus or minus 40 gallons per day (Mayer et al. 1999). A thoughtful conservative choice allows for individual variations, and in most situations creates a longer lasting system.

Non sewage sources

Clear water additions

Clear water (including groundwater, rainwater, surface water, condensate, ice machine drainage, and/or discharge from pools, hot tubs, and water treatment devices) fits into this category. Sources of clear water should not be directed to the system; if connected, they can create problems in the system. A number of water-using devices (such as water softeners, iron filters and water treatment devices) do not produce sewage as defined in MN Rules Chapter 7080. These devices do produce effluent, but that effluent has not come in contact with humans or laundry to create contamination that needs to be treated or removed. Water treatment discharge is defined by CIDWT as the by-product from a water treatment device, such as regeneration water from an ion-exchange unit, reject

water from a reverse-osmosis unit, or backwash from an iron filter using and does not need to be directed to a SSTS.

Water softeners reduce the number of or remove calcium and magnesium ions, which are the principal causes of hardness in water. Cation exchange resin method is most commonly used for residential and commercial water treatment. Water softener and iron filter recharge water adds a large volume of water to the system – typically 30 to 80 gallons per cycle. This is water that does not require treating.

A growing concern with water softener recharge water is that it may cause an increase in the amount of solid material that remains suspended in the liquid layer (effluent) in the septic tank and ends up in the drain field trenches or a mound. These solids may shorten the life of the soil treatment system, increasing the chance of drainfield or mound failure. Water softener discharge has conflicting results in research studies, but it does appear that scum layers are often absent in tanks where the water softener recharge water enters the septic tank.

Iron filters

Iron or manganese in water does not present a health hazard, although there are some concerns that manganese in high levels can harm the nervous system. Their presence in water may cause taste, staining and accumulation problems in the plumbing system. Iron and manganese deposits will build up in pipelines, pressure tanks, water heaters and water softeners. This can reduce the available quantity, quality and pressure of the water supply. Iron and manganese accumulations become an expensive problem when water supply or softening equipment must be replaced. In addition, pumping water through constricted pipes or heating water with rods coated with iron or manganese minerals increases energy costs. A related problem is iron or manganese bacteria. These nonpathogenic microbes feed on iron and manganese in water. They form red-brown (iron) or black-brown (manganese) slime in toilet tanks and can clog water systems.

Standards for iron and manganese are based on levels that cause taste and staining problems and are set under EPA Secondary Drinking Water Standards. For most individuals, 0.3 parts per million (ppm) of iron and 0.05 ppm of manganese is objectionable. Usually iron and manganese do not exceed 10 ppm and 2 ppm, respectively, in natural waters. Iron and manganese can be found at higher concentrations; however, that condition is rare.

How do iron filters work?

For household water containing high levels of iron and manganese, the most common solution is a process using oxidation followed by filtration. Oxidation is accomplished by introducing an oxidant (such as oxygen) into the raw water. Sources of oxygen included the air as well as chlorine or potassium permanganate. Through a series of chemical reactions, oxidation converts soluble contaminants into insoluble solid particles. The solidified contaminants are then filtered out, and the backwash cycle removes the filtered particles from the filter.

Most iron filters remove both clear water iron and ferric iron (rust). Even water that is clear in color may contain high levels of iron. This is known as ‘ferrous’ or clear water iron. Using the oxidation process described above, home iron filters take this clear water iron (ferrous iron) and precipitate it into small particles of iron solids (ferric iron) that can be captured by a mechanical filter. These trapped particles are periodically and automatically backwashed out with the flush/backwash of the filter, usually once or

5-4 ■ SECTION 5: Wastewater Sources and Flows

twice a week. This typically results in 150-200 gallons per backwash cycle resulting in 10,000 - 20,000 additional gallons of wastewater with these iron solids being discharged annually. If being discharged to a septic system, long-term system performance may be at risk.

It is uncertain what happens to the particles that are backwashed from the filter, and into a septic system, but there are several potential hazards that can impact system performance:

1. The solids should settle out in the sludge layer of the septic tank and increase the need for maintenance.
2. During times of turbulence or if sludge depths get too thick this material may travel through the septic tank to downstream components. This material can create challenges in a pretreatment system and/or the soil treatment area. In the soil treatment area, it may cause growth and plugging in the piping systems and plugging in the soil itself.
3. In the anaerobic environment of the septic tank, the insoluble iron is converted to soluble iron going into solution and traveling out of the septic tank and downstream. There is then the risk in the aerobic environment following the septic tank that the iron will be made insoluble again, form a precipitate and potentially clog piping and the soil treatment system.

Can a water softener be used to remove iron?

Water softeners remove hardness using a resin and remove dissolved clear water iron by a process known as ion exchange. However, iron, manganese and/or hydrogen sulfide gas will eventually overwhelm the resin causing fouling and failure of the ion-exchange resin. If your water contains less than 2.0 ppm of iron and manganese combined, and no sulfur odor, then a good quality water softener with a special type of resin cleaner in the brine tank will work. The resin cleaner will help clean the resin when the softener is being regenerated with the brine solution. If not, a home may need both an initial iron filter followed by a water softener. In this case, the water softener discharge water should be dealt with in the same manner as the iron filter discharge.

Challenges

There are three potential challenges related to iron filters and septic systems:

- 1. Iron filter recharge chemicals may contain a bleaching or sanitizing agent, which is detrimental to bacterial action in the septic system.
- 2. The additional water (150 to 200 gallons to recharge and backwash) several times a week adds additional wastewater into the system. Depending on other use in the home, the additional water to the septic tank and soil treatment area may cause problems with septic system operation or may overload it.
- 3. If the solids are suspended in the septic tank effluent or re-solubilized, they may plug downstream components.

Options

If possible, the water used for outside use and irrigation should not be filtered. This will reduce the amount of water treated and the amount of particles. Discharge of iron filter backwash to a septic system is not recommended due to the nature of these solids.

SECTION 5: Wastewater Sources and Flows ■ 5-5

Below are some options to consider:

- 1. New home? If a water treatment device is needed due to the source of water at the home, then the backwash discharge may be incorporated into the design of the septic system. In this case there are two options:
 - a. Preferred: Install a separate soil treatment system for the regeneration water which includes a septic tank to settle out the solids. If a septic tank is not installed the separate system will likely plug over time. The trench bottom must be above the periodically saturated soil or bedrock and trench must meet water supply well setbacks.
 - b. Secondary option: Discharge to the surface; not directly into a surface water, wetland or intermittent stream where water must soak into the ground where it has been discharged. Discharge must stay on the property and not cause erosion or nuisance conditions.
 - c. Less preferred: Install a larger septic tank (double the capacity is the recommended minimum) with an effluent screen and alarm and clean the septic tank annually while evaluating sludge level.
- 2. Existing home: The best solution for an existing home will depend on the plumbing system and the related costs. This may require the installation of a sump in the basement or crawl space to collect the backwash water.
 - a. Whenever possible the backwash water should be routed to another location (see a and b above).
 - b. Maintain septic tank annually to remove settled particles.

Reverse osmosis is a separation process that uses pressure to force water through a membrane that retains the solute contaminants on one side and allows the pure solvent to pass to the other side. More specifically, it is the process of forcing a liquid from a region of high solute concentration through a membrane to a region of low solute concentration by applying a pressure in excess of the osmotic pressure. This is the reverse of the normal osmosis process, which is the natural movement of solvent from an area of low solute concentration, through a membrane, to an area of high solute concentration when no external pressure is applied. The membrane here is semi-permeable, meaning it allows the passage of liquid but not of solute or particles.

The membranes used for reverse osmosis have a dense barrier layer in the polymer matrix where most separation occurs. In most cases, the membrane is designed to allow only water molecules to pass through this dense layer while preventing the passage of solutes (such as salt ions). This process requires that a high pressure be exerted on the high concentration side of the membrane, usually 2–17 bar (30–250 psi) for fresh and brackish water, and 40–70 bar (600–1000 psi) for seawater, which has around 24 bar (350 psi) natural osmotic pressure which must be overcome.

Reverse osmosis units sold for residential purposes offer water filtration at the cost of large quantities of waste water. For every five gallons of output, a typical residential reverse osmosis filter will send around ten to 20 gallons of water down the drain (although many people capture it and use it for watering plants and lawns). In some states this water is used for irrigation.

High-efficiency furnaces operate at a high efficiency and therefore save on energy use. One of the results of the heating process is that condensation occurs in the unit. When

5-6 ■ SECTION 5: Wastewater Sources and Flows

this condensation builds up, water slowly trickles out of the unit and into the plumbing that is often connected to an onsite system. This water can cause freezing problems in the onsite system because of the slow, steady flow. In addition, this water is clean and therefore does not need to be treated. When the furnace is in operation, this water typically trickles out of the unit at a volume of five to ten gallons on a cold day.

In high-efficiency furnaces, the recharge water from water softeners and iron filters has the potential to cause problems with onsite sewage treatment systems.

Industrial wastewater

Industrial wastewater is the water or liquid-carried waste from an industrial process resulting from industry, manufacture, trade, automotive repair, vehicle wash, business or medical, activity that may contain toxic or hazardous constituents.

Garage floor drain liquid wastes from garages serving single and multi-family homes can consist of the following:

- Precipitation draining from vehicles and liquids from vehicle washing
- Spills from materials stored or used in the garage such as: Thinners, solvents, paints, pesticides, cleaners, etc.
- Liquids from vehicle repair such as: gasoline, used oil, antifreeze, other

Therefore, there is a potential for hazardous waste and other damaging waste entering the floor drain system.

Always check with local units of government for specific requirements. The following list is provided in preferential order of how to handle liquid wastes from private garages:

Preference #1: Do not install floor drains in new constructions of private garages; instead, slope the floor to the doors. For existing garages, seal the drain to prevent further discharge.

Preference #2: If a floor drain is desired, the floor drain may discharge to the homeowner's lawn surface if approved by the administrative authority (MN R. Chapter 4715.1300, subp. 6). The discharge area must be visible, and cannot drain or convey runoff directly to storm drains or ditches. The good housekeeping practices described below must be followed.

Preference #3: If a floor drain is desired and the home is connected to the municipal sanitary sewer, connect floor drain to the home's building sewer for sanitary wastes. Connection must be in compliance with the Plumbing Code (MN Rules Chapter 4715.1300). The hookup should comply with the local sewer use ordinance, and may be subject to local approval. The good housekeeping practices described below must be followed.

DO NOT:

- direct the floor drain waste to a street, ditch or water body (MN Rules Chapter 7050.0210, sub 2),
- connect to building sewer of homes served by individual sewage treatment systems (ISTS) (MN Rules Chapter 7080.0065),
- allow the floor drain to "deadhead" into the soil (MN Rules Chapter 4715.1300).

Good Housekeeping:

- Care should be taken that hazardous or other damaging waste does not come in

contact with the garage floor. Any hazardous or other damaging waste reaching the garage floor must be absorbed and disposed of at a household hazardous waste facility. No hazardous or other damaging waste should be discharged to daylight via a floor drain or sloped floor, or to a floor drain connected to sanitary sewer (MN Rule Chapter 7060, subp 2). All used oil must be recycled (MN Statute 115A.916).

- Homeowners have the duty to avoid and mitigate pollution from any of the preferred disposal options (MN Statutes 115.061). Any non-hazardous/non-damaging liquid waste discharged to daylight via a floor drain or sloped floor must not create a nuisance condition or contaminate storm water runoff (MN Rule Chapter 7050.0210).
- If a floor drain remains in the garage, it is recommended that a permanent sign or plate be placed on or within view of the drain stating, “WARNING - Water Only! Floor drain leads to our water supplies”.

Other Establishments

Domestic sewage is also generated by Other Establishments. **Under Chapter 7081, an “other establishment” is any public or private structure, other than a dwelling, that generates sewage and discharges it to an MSTs (7081.0020, Subp. 6).** Other establishments may have large flows and/or high-strength waste, so Chapter 7081 has special regulations for them. These systems are also regulated by the EPA Class V Rules and must complete an inventory form available at septic.umn.edu/ssts-professionals/forms-worksheets.

Non-domestic waste is generated by many sources, such as restaurants, laundromats, barber shops, car washes and other light industrial establishments. Waste other than sewage is only allowed to be discharged into a SSTS if the waste is suitable to be discharged to groundwater. If waste strength parameters exceed the values identified in MN Rules Chapter 7081.0130, Subp. 2, the system should include pretreatment.

A range of systems can be designed for Other Establishments.

- a. Type I – if domestic levels of wastewater can be achieved with septic tanks alone the system is classified as at Type I system.
- b. Type II or III - if site or soil conditions are limiting.
- c. Type IV – if the system uses a registered product (Treatment Level C) to reduce waste strength the system is considered to be a Type IV system.
- d. Type V – if the system uses a non-registered product to reduce the waste strength the system is considered to be a Type V system.

The focus of Minnesota’s septic system program in the 1970’s was to identify technical standards for systems that treated sewage from dwellings. At that time, not much thought was given to the treatment challenges of waste generated by structures other than dwellings, which were creatively referred to in rule as “other establishments”. This led to an era of frequent premature system failures, especially for the facilities like restaurants that produced the highest strength waste. Requirements changed as the industry learned from its experiences, and we began specifying more specific standards for systems that treat high strength waste. While we may use pretreatment devices on restaurants creating high strength waste, we have not adequately answered the question

5-8 ■ SECTION 5: Wastewater Sources and Flows

of how to ensure effective treatment for the other establishments with waste strength greater than dwellings but less than the obviously high strength waste from restaurants.

Local program data suggests that we continue to struggle with identifying the proper wastewater treatment solutions for other establishments. Local programs have reported over 8,500 non-residential establishments being served by septic systems in Minnesota.

The right questions about waste strength need to be asked when designing or reviewing systems for other establishments. Septic systems that serve complex waste streams need extra attention to ensure they provide long-term and cost effective treatment. We all learned that the relationship between hydraulic loading and organic strength is fundamental to effective wastewater treatment. The two questions are the treatability of the effluent and the actual organic loading of the effluent.

Code Requirements

Minnesota Rules Chapters 7080 - 7083 are very clear about the fact that other establishments are different than dwellings (7081.0020 Subp. 6). The rules are also very pointed about the limitations of flow-derived design calculations (7080.2150 Subp. 3, item K), and the need to provide additional treatment for systems serving establishments that generate non-residential strength waste. The first step in designing any septic system in Minnesota is to determine the design flow and anticipated waste strength concentrations (7080.1710 Item A) if they are different than residential.

The code does not prescribe how to anticipate the waste strength or what to do when we expect waste strength to exceed residential strength waste. The code also does not explicitly state that all other establishments produce waste strength that exceeds residential values. Research and experience does suggest that we need to pay special attention to other establishments, and it is safest to assume that all other establishment sewage exceeds residential strength values. Forms of additional treatment that are not pretreatment could include specifying extra tank capacity, grease traps, effluent screens, pressure distribution, larger soil dispersal systems, flow equalization, flow-splitting, more frequent maintenance, and other methods. Some residential permits may produce non-residential waste strengths. These would include residential treatment facilities, rental properties, bed and breakfast facilities, daycares or other in-home businesses.

Related Licensing Requirements

Another factor comes into play when we ask which specialty area (basic, intermediate, or advanced) is required to design and inspect systems serving other establishments. The SSTS program wasn't built around the types of structures the systems serve - it was built around the sewage that needs to be treated and the system types that perform the treatment. Basic designers and inspectors are authorized under 7083.0740/0750 Subps. 1 to design, permit and inspect Types I, II, or III SSTS serving dwellings or other establishments. Intermediate or Advanced certification is currently required when the system uses pretreatment. Appropriately matching a treatment solution to a complex waste stream is complicated, and proper certification is necessary. In fact, it was one of the reasons that the advanced design and inspection certifications were introduced in the first place.

The size of the absorption area should be sized on the greater of the maximum hydraulic load or the maximum organic load. See Table 5.1 and calculations to determine

SECTION 5: Wastewater Sources and Flows ■ 5-9

sustainable organic loading. It may be advisable to oversize the absorption area by 50% and divide the system into 3 zones for dosing and resting cycles if secondary treatment is not employed (a must for MSTs - [MN Rules Chapter 7081.0270, Subp. 5 B 3](#)).

TABLE 5.1 70% (sustainable) Organic Loading Table			
Soil Texture	Sustainable BOD Loading (lbs/ft ² /day)	Sustainable TSS Loading (lbs/ft ² /day)	Sustainable FOG Loading (lbs/ft ² /day)
All Sands	0.001191	0.00042	0.000175
Sandy loam	0.000774	0.000273	0.000114
Fine sand, loam	0.000595	0.000210	0.00088
Silt loam	0.000496	0.000175	0.000073
Clay loams	0.000447	0.000158	0.000094

* These values are 70% of maximum allowable organic loading rates for Type I systems to provide a more representative waste loading versus a peak waste loading.

To calculate:

1. BOD Loading -

$$\frac{\text{BOD conc. from treatment device (mg/L)}}{8.35 \div 1,000,000} \times \text{Hydraulic loading rate (gal/ft}^2\text{/day)} = \text{Waste strength loading rate (lbs/ft}^2\text{/day)}$$

2. TSS Loading -

$$\frac{\text{TSS conc. from treatment device (mg/L)}}{8.35 \div 1,000,000} \times \text{Hydraulic loading rate (gal/ft}^2\text{/day)} = \text{Waste strength loading rate (lbs/ft}^2\text{/day)}$$

3. Oil and Gease Loading -

$$\frac{\text{O \& G conc. from treatment device (mg/L)}}{8.35 \div 1,000,000} \times \text{Hydraulic loading rate (gal/ft}^2\text{/day)} = \text{Waste strength loading rate (lbs/ft}^2\text{/day)}$$

Some “other establishments” include the following:

Apartment buildings

Rental situations have been known to have overuse of the system. The renter may not understand the impacts of their usage habits on the system and may have little concern about over using water. Multiple families can also impact the loading to the system. Low-flow fixtures and appliances along with education can assist in the management of the system.

Day cares

Day cares are always going to have higher flows associated with their use. The other concern here will be the cleaners that are used and the type of food that is available. In-home daycares will have higher flows than are typical for the number of bedrooms

5-10 ■ SECTION 5: Wastewater Sources and Flows

in the house due to the amount of people that are in the home and the amount of time they are there. The kitchen or waste strength will be similar to a normal home. The use of cleaners must be watched in these systems. Excessive cleaning, which is common in day cares, can lead to the killing of the bacteria and lower efficiency in the treatment tanks.

Commercial kitchen

A commercial kitchen is a food preparation center that prepares multiple meals or food products and typically generates high-strength wastewater. The food service wastewater from these facilities is non-toxic, non-hazardous wastewater and is similar in composition to domestic wastewater, but which may occasionally have one or more of its constituents exceed typical domestic ranges. It includes all the sewage wastes from commercial food preparation, food processing or food production sources.

Restaurants and bars almost always have high-strength waste that makes sewage treatment difficult. For this reason, a number of best management practices can be taken to facilitate treatment:

- Limit food particles and alcohol going down the drain.
- Limit the use of chemicals going down the drain: chemicals can kill the treatment system's good bacteria.
- Limit use of degreasers, even in cleaning supplies.
- A grease interceptor, a watertight device designed to intercept, congeal and retain or remove fats, oils, and grease (FOGs) from food-service wastewaters; should be located outside (grease tank or grease trap) of a facility that generates commercial food service wastewater. Some new products are being researched for inside applications.
- Isolate kitchen waste from other sewage production.
- Design tanks for a minimum of four to seven times the daily flow.
- Be aware that high water temperatures (140°F) do not allow grease to solidify, adding to treatment concerns.
- More tanks in series can help cool effluent.
- Be aware that septic tanks alone usually will not create residential strength waste.

When available the Designer or Service Provider should test the effluent from the last septic tank or pump tank to determine BOD/TSS/FOG levels.

Design considerations include:

1. Provide and maintain grease interceptor
2. Place clean out outside structure in the lines. Schedule regular line cleaning to avoid emergency services
3. Keep the first outside tank close to the establishment (i.e. a short building sewer) to keep the sewage from cooling and grease solidifying in the building sewer
4. If fat and grease are excessive, more and smaller tanks are better for cooling as there is more surface area contact with the soil. However an individual tank in series must still not be less than 25% of the total liquid capacity (MN Rules Chapter 7080.1940 B).
5. Tanks must be sized on retention time to promote adequate cooling, floatation and settling. Typical retention time for domestic wastes is 3 to 4 days. (daily flow x 3, or

SECTION 5: Wastewater Sources and Flows ▪ 5-11

- daily flow x 4). More retention time is likely needed for high strength wastes. The frequency of solids removal should also be considered when determining tank size.
6. If fat and grease are excessive, more capacity above the liquid level and higher baffles may be advisable. Effluent filters should (must for MSTs) be used on the final tank in series.
 7. Deeper inlet baffles will create better mixing and facilitate cooling of the effluent.
 8. For high strength waste situations, it is recommended that the orifice size for pressure distribution system be no smaller than 1/4 and the distal head should be no less than 5 feet. Cleanouts must be provided (**MN Rules Chapter 7080.2050 sub. 4J**). More frequent doses are preferable (min of 4 doses/day is required by rule), as long as the dose volume equals or exceeds four distribution pipe volumes plus the volume of the supply pipe.
 9. The size of the absorption area should be sized on the greater of the maximum hydraulic load or the maximum organic load. See Table 5.1 and calculations to determine organic loading. It may be advisable to oversize the absorption area by 50% and divide the system into 3 zones for dosing and resting cycles if secondary treatment is not employed (a must for MSTs – **MN Rules Chapter 7081.0270, Subp. 5 B 3**).

Campgrounds

At campgrounds, it is likely that users unfamiliar with onsite treatment systems will be adding waste to the systems. Peak flows are often very high; for this reason, consider extra tank capacity, commercial-size effluent filters, and the use of timers. Pretreatment may also be needed to get the levels of the effluent down to domestic levels.

Privies

- Pit Privies must have three feet of separation below the point where sewage enters soil
- Vault Privies must meet all requirements of holding tanks
- Minimum size = 25 ft³
- More information on Privies is detailed in Section 7

RV Dump Stations

- At RV dump stations, there is the potential for odor-control chemicals (OCC) that may be harmful to the system, including:
 - Formaldehyde (OCC): the organic strength is so high that the resulting mixture in a holding tank is fifteen to twenty times stronger.
 - Quats (OCC) are not biodegradable and deodorize by killing the odor-causing microorganisms.
 - Non residential enzyme -based products employ natural organic chemicals. Because they are less effective, they are not used much.

Consider operating the dump station as a holding tank if OCC are in the waste stream. Pretreating the RV waste or slowly time-dosing the RV waste to the rest of the treatment system is another option. Dump stations should be designed with excessive tank capacity. UMN recommends a 3 or 4 day retention time for holding tank sizing based

5-12 ■ SECTION 5: Wastewater Sources and Flows

on the maximum number of trailers using the facility per day (40 gallons per day per trailer site).

Laundromats

The treatment of wastewater from laundromats is often compromised by their high use of soap, chemicals, and water. Steps can be taken to mitigate these factors, including:

- Use liquid soaps only; some cheap powders have excessive fillers
- Sell only liquid soaps which do not have a bleach additive
- Consider doubling tank capacity
- Use of low water use washing machines
- Use of lint filters in facility
- Use of a commercial-size effluent filter on septic tank
- Increase outlet baffle size to 50-60% of tank depth

Office Buildings

Flow varies greatly from one office building site to the next. In general, there is the potential for high-strength waste due to low graywater content. There is also the potential that users will be unfamiliar with onsite treatment systems. System designers should be aware of any cooking facilities that may be present in the building, and should consider a commercial-size effluent filter when there is the potential for high-strength waste.

Schools and Churches

Because of the potential for high-attendance events to be held at schools and churches, peak flows can be quite high at times, and it is likely that users will be unfamiliar with onsite systems. Consider extra tanks, timers and dual fields so one can be rested. System designers should ask if a cooking facility is present. If so, the waste will be high strength and will require additional design considerations. Consider commercial-size effluent filters.

Hotels and Motels

Again, there is the potential that users at hotels and motels will be unfamiliar with on-sites. System designers should ask if a cooking facility is present. Consider commercial-size effluent filters. If the facility is seasonal, consider dual fields to rest and help with freeze protection.

Medical Facilities

There is the potential for users unfamiliar with onsites. There is also the potential for harmful chemicals to enter the system, including left-over medicine and cleaning chemicals. Leftover medications should not be flushed down the toilet and janitorial staff should be educated about the appropriate use of cleaning chemicals to ensure a sanitary environment while minimizing product use. Sharps/red bag waste must not go into system. Consider commercial-size effluent filters. The well setback for medical facilities is increased to 150' for systems serving this type of waste.

Beauty Salons and Barbers

Hair and other chemicals should be minimized entering the system. Good catch basins/screens should be placed in sinks. Have one sink for rinsing out perms/hair color

that drains to a holding tank, as the chemicals used in these processes can be hazardous. Consider a commercial-size effluent filter.

Automotive Garages

No floor drains where vehicle maintenance is being performed should drain to a SSTS. Instead, these drains should go to a holding tank. Flammable waste traps are a good idea in case of spills or misuse. Hazardous waste can not be allowed to enter the system. If a thick layer of oil/grease forms on top of the tank, laboratory analysis should be conducted to determine what the layer is composed of and should be checked for hazardous waste. If there is no hazardous waste, the wastewater may be thinly land applied or brought to a permitted waste treatment facility.

Filling Stations, Service Stations, Car Washes

The oil and grease wastes from a filling station or car wash can not be allowed to flow into a septic system. Such wastes, including floor washing wastes from the service bay, should be discharged into a holding tank which is pumped and cleaned when full. EPA prohibits floor drain waste from a service station from entering an onsite system. Only the toilet wastes from a service station should flow into a septic tank and subsurface soil absorption system. See septic.umn.edu for more information about systems for these establishments.

All of these facilities have a high potential for hazardous waste. As a Designer, be sure to communicate the care of these chemicals and the responsibility to control their discharge. As a professional developing a simple care plan is also important for the proper operation of the facility.

Flow Determination for Clusters & Other Establishments

When a single onsite system is designed to treat an average design flow greater than 10,000 gallons per day, the owner or owners must apply for a state disposal system (SDS) permit from the Minnesota Pollution Control Agency. A professional engineer (PE) must be involved in the design of any SSTS that requires a SDS permit. According to MN Rules Chapter 7081.0040, Subp. 1:

- a. All MSTs must be designed and operated according to this chapter, except as modified through an ordinance in compliance with chapter 7082 and Minnesota Statutes, section 115.55. All MSTs must be designed, installed, inspected, pumped, and operated by a qualified employee under part 7083.1010 or a licensed business under part 7083.0710. All MSTs must conform to applicable state statutes and rules.
- b. The owner or owners of an SSTS must obtain an SDS permit from the agency according to chapter 7081 when:
 - (1) a single proposed or existing soil dispersal area receives a flow greater than 10,000 gallons per day; or
 - (2) when all proposed and existing SSTS soil dispersal areas that are under common ownership and within one-half mile of each other have a combined flow greater than 10,000 gallons per day. Flow from an SSTS with low impact to potable water is not counted in this subitem.
- c. An SDS permit is required for any subsurface sewage treatment system or group of subsurface sewage treatment systems that the commissioner de-

5-14 ■ SECTION 5: Wastewater Sources and Flows

termines has the potential or an increased potential to cause adverse public health or environmental impacts if not regulated under a state permit. Conditions for these permits include systems in environmentally sensitive areas, unsubstantiated or unexpected flow volumes, and systems requiring exceptional operation, monitoring, and management.

- d. If flow values, as determined according to part 7081.0110, are greater than 10,000 gallons per day but an SDS permit is not required because of subpart 1a, item B, flow measurement data generated for making that determination must be submitted to the commissioner for review before a local permit is issued. Information on all subsequent alterations to the flow must also be provided to the commissioner.

According to 7081.0040 Subp. 1a the following methods are required to determine flow to establish whether an SDS permit is required:

- A. For new SSTS and expansions to existing SSTS, the flow must be determined according to item C.
- B. For new existing SSTS, except as provided under item D, the flow is determined:
 1. by calculating the average of the maximum measured daily flow for a consecutive seven-day period when the following measurements are recorded and used in the calculation:
 - a. 90 consecutive daily flow measurements capturing the maximum use. Measurements must be corrected for occupancy or use according to Prescriptive Designs and Design Guidance for Advanced Designers, incorporated by reference under part 7080.1550, subpart 2; and
 - b. 40 additional, consecutive, weekly flow measurements validating that unit (a) captured the maximum use; or
 2. according to item C.
- C. The highest calculated value of the various methods in Table I Estimated Design Flows for Other Establishments, must be used to make the determination, with no reduction allowed. An SDS permit is not required if a factor of safety is added to the design flow that results in a design flow that exceeds the SDS permit threshold.
- D. Campgrounds and resorts existing as of June 14, 2015, that are open 180 days per year or less must determine flow in accordance with this item or item A or B.
 1. Flow Measurements must be taken only from:
 - a. a sewage lift station pump with a runtime meter and counter
 - b. a sewage flow meter
 - c. flow meters on wells
 - d. a water softener system with flow measurement when the measurement includes all flow to the subsurface soil treatment system, including backwash.
 2. Flow measurement devices must be calibrated before start-up of monitor-

ing and must undergo an additional calibration during the measurement period to verify results.

3. The daily flow rate and daily occupancy rate must be recorded for a minimum of two weeks centered on and including July 4. Weekly measurements must also be done for an additional, continuous two weeks before and two weeks after July 4.
4. Flow measurements must be divided by the percent occupancy expressed as a decimal percent
5. Flow extrapolation from systems not measured is allowed as follows:
 - a. flow may be extrapolated only if fewer than 25 percent of the systems are not measured
 - b. the systems measured must serve at least 75 percent of the occupancy of the campground or resort
 - c. flow extrapolation is not allowed between other campgrounds and resorts.
6. If no flow data exist, the owner or operator of the campground or resort must implement an acceptable flow measurement plan and start measuring and recording flow data within 120 days of notification. An acceptable flow measurement plan is a plan, verified by the agency, conforming to subitems (1) to (5).
7. All flow measurement data generated from the flow measurement plan must be submitted to the commissioner within 30 days of the last measurement.

For Other Establishments design flows are determined by the 3 options below:

1. Use Table I: Estimated Design Flow for Other Establishments. Unless otherwise noted in Table I, the flow values do not include flows generated by employees. A flow value of 15 gallons per employee per eight-hour shift must be added to the flow amount. Design flow determination for establishments not listed in Table I must be determined by the best available information and approved by the local unit of government. Flow for systems not designed for maximum, seven-day, daily use may be determined by averaging the estimated flow from Table i for a consecutive seven-day period if flow equalization is used and approved by the local unit of government. Maximum daily flow calculated under this item must be used to determine septic tank size.
2. The measured design flow of sewage for SSTS serving other establishments is the average of the maximum measured daily flows for a consecutive seven-day period. Measurements must be corrected for occupancy or use according to Prescriptive Designs and Design Guidance for Advanced Designers, incorporated by reference under part 7080.1550, subpart 2.
3. For SSTS using flow measurement as allowed in 7081.0040, subpart 1a(B), subitem (1), may expand based on those measurements according to the following:
 1. measured flow values may be used only for similar units

2. expansion above 25 percent of the total flow is not allowed unless the flow is re-measured or estimated values from Table I are used (See section 13).
3. measured flow values may not be used at any other facility of property.

Class V Inventory Form (EPA regulations)

These forms are required for all facilities that meet the following requirements:

- on-site sewage treatment systems serving 20 or more people,
- facilities that generate waste other than domestic waste, and
- inventory form must be completed and copies sent to the EPA (address listed on the form).

Hydraulics – Flow Rates

7080 Versus 7081

7080 is the rule reference for determining design flows for domestic systems from dwellings with flows less under 5,000 gpd. However, **7080.1880 states that design sewage flow and waste concentration levels for other establishments with a flow of 5,000 gallons per day or less shall be determined by part 7081.0130.**

Chapter 7081 applies to MSTs cluster systems which have flows from 5,000 to 10,000 gpd. There are many terms that apply to cluster systems that are commonly used.

- Cluster system is the sewage collection, treatment, and dispersal system designed to serve two or more sewage-generating dwellings or facilities. This implies a planning concept incorporating green space and common wastewater treatment.
- Collector system is typically an older development that needs to treat the wastewater offsite incorporating a collection system.
- Decentralized system includes the collection, treatment, and dispersal/reuse of wastewater from individual homes, clusters of homes, isolated communities, industries, or institutional facilities, at or near the point of waste generation.
- Distributed sewer system is an area-wide system of individual, community, and cluster wastewater treatment systems that is managed by one or more management entities. Systems may include all forms of treatment, dispersal, discharge, reuse or recycle alternatives.

In both Chapter 7080 and 7081 the design flows calculated are flow maximums, meaning that the systems should not actually receive this amount of wastewater daily to ensure long term performance. It is recommended that the average flow to the system be less than 70% of the design flow.

General Hydraulic Considerations


There are numerous terms used to apply to hydraulics and flow that a professional needs to understand in the design and operation of a SSTS:

- Flow rate, average daily: average volume of wastewater in a 24-hour period; calculated from values measured over a period of time

SECTION 5: Wastewater Sources and Flows ▪ 5-17

- Flow rate, daily: measured volume of wastewater generated from a facility in a 24-hour period; expressed as a volume per day
- Flow rate, daily design: estimated peak volume of wastewater for any 24-hour period; parameter used to size non-residential systems
- Flow rate, design: estimated volume of wastewater per unit of time for which a component or system is designed; commonly called 'design flow'; see flow, design
- Flow rate, peak hourly: highest flows measured for a one-hour period
- Flow rate, peak instantaneous: highest recorded flow rate occurring within a given period of time
- Flow surge: flow of effluent greater than average and occurring for short periods of time
- Flow equalization: system configuration that includes sufficient effluent storage capacity to allow for uniform flow to a subsequent component despite variable flow from the source

Figure 5.2 charts the flow entering a system over the course of a week and graphically identifies many of the above terms.



Design Process for Flow Equalization

1. The tank capacity is determined by adding:
 - a. the minimum volume required to keep the pump submerged,
 - b. a surge volume equal to the flow generated during the designated storage period plus the design flow, and

- c. the reserve volume above the alarm activation level.
2. It is recommended that the equalization tank be designed to hold at least twice the average daily flow of the facility and dose it over the course of more than a single day.
3. The flow from a surge or flow equalization tank is controlled by a timer that controls pump operation according to fixed on (dose) and off (rest) cycles. Effluent delivery can then be spread out over several days.

See the MPCA publication, “Prescriptive Designs and Design Guidance for Advanced Designers” for more information about flow equalization.

Estimates of Flow for Dwelling Design

The estimates of flow used in Minnesota to size sewage treatment systems allow for a safety factor so that systems will function properly even when serving a residence or other establishment with higher than average rates of water use. Chapter 7080 specifies estimated sewage flow rates depending upon the size of residence and the number of water-using appliances.

From 7080.1850, Subp.1 & 2, if construction of additional dwellings or bedrooms, the installation of water-using devices, or other factors likely to affect the operation of the ISTS can be reasonably anticipated, the system must be designed to accommodate these factors.

The estimated design flow for any dwelling must provide for at least two bedrooms. For multiple or multifamily dwellings, the design flow consists of the sum of the design flows for each individual unit. A bedroom is defined in 7080.1100, Subp. 9, is an area that is:

- a. a room designed or used for sleeping; or
- b. a room or area of a dwelling that has a minimum floor area of 70 square feet with access gained from the living area or living area hallway. Architectural features that affect the use as a bedroom under this item may be considered in making the bedroom determination.

The estimated sewage flows presented in Table 5.2 are based on the number of bedrooms in a residence. Because the individuals who occupy a residence use the water, the number of bedrooms is considered a good index of the potential water use. For a Class I residence, the estimated water use is equal to 150 gallons per day (gpd) per bedroom. This assumes occupancy of two people per bedroom, each using 75 gpd. This is a conservative estimate for many residences, although it may be low for large and high-value residences. The notes in Table 5.2 suggest a classification for the various types of residences according to home size and number of water-using appliances.

Dwelling does not include a single-family or multifamily residence that serves both as a domicile and a place of business. If the business increases the volume of sewage above what is normal for a dwelling, a designer should add the additional flow from the business to the values in Table 5.2. If the liquid waste generated from business operations no longer qualifies as domestic sewage, additional design considerations must accommodate the waste type and strength.

**TABLE 5.2 Estimated Sewage Flows in Gallons per Day
(from MN Rules Chapter 7080.1860 Table IV)**

Number of Bedrooms	Class I	Class II	Class III	Class IV
2 or less	300	225	180	*
3	450	300	218	*
4	600	375	256	*
5	750	450	294	*
6	900	525	332	*

* Flows for Classification IV dwellings are 60 percent of the values as determined for Classification I, II, or III systems. For more than six bedrooms, the design flow is determined by the following formulas:

Classification I: Classification I dwellings are those with more than 800 square feet per bedroom, when the dwelling's total finished floor area is divided by the number of bedrooms, or where more than two of the following water-use appliances are installed or anticipated: clothes washing machine, dishwasher, water conditioning unit, bathtub greater than 40 gallons, garbage disposal, or self-cleaning humidifier in furnace. The design flow for Classification I dwellings is determined by multiplying 150 gallons by the number of bedrooms.

Classification II: Classification II dwellings are those with 500 to 800 square feet per bedroom, when the dwelling's total finished floor area is divided by the number of bedrooms, and where no more than two of the water-use appliances listed in Classification I are installed or anticipated. The design flow for Classification II dwellings is determined by adding one to the number of bedrooms and multiplying this result by 75 gallons.

Classification III: Classification III dwellings are those with less than 500 square feet per bedroom, when the dwelling's total finished floor area is divided by the number of bedrooms, and where no more than two of the water-use appliances listed in Classification I are installed or anticipated. The design flow for Classification III dwellings is determined by adding one to the number of bedrooms, multiplying this result by 38 gallons, then adding 66 gallons.

Classification IV: Classification IV dwellings are dwellings designed under part 7080.2240.

The determination of what constitutes a bedroom may seem to be an easy process; however in some cases, it has proved to be a difficult task. It should be clearly understood that the definition of a bedroom in 7080.1100, Subp. 9 is intended to be used only to estimate sewage flow from the dwelling. It must not be used to determine the adequacy or safety of a room for sleeping purposes. Please refer to the International Residential Code (www.iccsafe.org), the Minnesota State Building code (www.dli.mn.gov/cclld/codes.asp), or other pertinent building codes for those requirements.

The definition of bedroom was crafted to be as specific as possible to address a majority of the flow determination situations that will be encountered. However, there may be unique situations in which this definition may need to be interpreted. Excerpts from the MPCA's fact sheet, "Bedroom Definition for Determining SSTS Size" are offered below to provide guidance to designers and inspectors in making these unique determinations.

The main complication in crafting a definition of a bedroom is the differences between older and newer dwellings. Older dwellings were not built to a code, while newer dwellings are constructed under very detailed codes. Therefore, rooms used as bedrooms can be markedly different from older to newer dwellings. If Chapter 7080 were to be used as a bedroom definition based on a current building code, it would wrongly exclude rooms as commonly used as bedrooms in older dwellings.

A survey was taken of local SSTS administrators to aid in crafting the bedroom definition. The survey results focused on two main issues - current use and architectural issues.

5-20 ■ SECTION 5: Wastewater Sources and Flows

Current Use

MN Rules Chapter 7080 is clear that if a room or area (even if it does not meet the size or access requirements) is currently being used as a sleeping room, it is counted as a bedroom. This includes an area used for sleeping which may be unsafe. Again, this bedroom determination is to estimate flow, not to determine the safety of the room for sleeping.

Exceptions can be made if the occupant who is using the room for sleeping is temporary. Examples would be:

- an adult child with family who has temporarily moved-in during construction of their new dwelling, and
- occasional guest(s) who sleep on a sofa-sleeper in a common living area

Other useful sources for determining if a room is a bedroom include:

- The current or most recent real estate listing of the number of bedrooms
- The number of bedrooms listed with the local Assessor's office
- Rooms labeled as bedrooms on the house plans
- Rooms with smoke detector
- All rooms on a second level that are not bathrooms

Architectural Issues

These are features common to designated bedrooms or rooms used as sleeping areas:

- Rooms or areas with legal egress
- Rooms with a closet
- Rooms which are adjacent to a three-quarter bathroom

Rooms such as dens, sewing rooms, exercise rooms and home theaters should also be given serious consideration as a bedroom as they have the potential to be easily converted.

Architectural features that are obstacles to the use of a room as a bedroom include:

- Rooms that are obviously a kitchen, bathroom, living room, dining room, laundry room, storage room (without windows) or family room
- Rooms and areas with low ceilings
- Rooms with arched doorways that lack a door
- Rooms and areas with half walls
- Rooms and areas with no privacy
- Rooms and areas without egress to the outside
- Rooms and areas with no source of light and ventilation to the outside
- Rooms and areas that are used as a passage to other rooms, stairs, or bathrooms unless this is the only sleeping area in the dwelling
- "Open" lofts

A minimum ceiling height is seven feet for basements and seven feet, six inches for upper floors; for attic areas having downward-tapering ceilings a minimum height of five feet is allowed. Areas less than five feet in height are not included in the 70 sq. ft. minimum floor area calculation.

LGU ordinance considerations

The following are examples of ordinance amendments being used by some LGUs to address whether or not a questionable room is counted as a bedroom. These may not be applicable to all LGUs.

1. Requiring documentation from builder/owner of a permanent feature that precludes the use of the room as a bedroom
2. Limiting the number of bedrooms for a typical single family dwelling
3. Requiring a minimum number of bedrooms for a typical single family dwelling
4. Requiring techniques to insulate the system if freezing is a concern for a dwelling with a large number of bedrooms but a water use well below the design volume

Financial considerations

Typically, the increase in cost of adding an additional bedroom to a system design is not exorbitant. A larger system size adds longevity and often recaptures the additional cost over the life of the system.

Sample bedroom determinations

Table 5.3 below offers some common situations, suggestions on the bedroom determination, and reasons supporting suggested determination. Always remember to check with the LGU to see whether they have stricter provisions in their ordinance.

TABLE 5.3 Bedroom Determination		
Room description	Bedroom?	Supporting reasoning
Den, exercise room or sewing room on house plan that is > 70 ft ²	Yes	Meets minimum size requirements and has no precluding architectural features
Room used as bedroom in an existing dwelling that is < 70 ft ² and has no egress	Yes	Currently being used as a bedroom
Laundry room in existing dwelling is > 70 ft ²	No	Plumbing, sinks, and washer/dryer are obstacles to use as a bedroom
Open loft in existing dwelling used as a bedroom	Yes	Currently being used as a bedroom
Open loft on house plan	No	“Open” is a an obstacle to use as a bedroom
Open loft in existing dwelling currently used as a play room	No	Not being used as a bedroom, and “Open” is an obstacle to use as a bedroom
Basement room >70 ft ² with egress	Yes	Meets Rule requirements of size and architectural features
Basement >70 ft ² without egress	No	Lack of egress is an obstacle to use as a bedroom

Use the Design Summary Worksheet, available at septic.umn.edu/ssts-professionals/forms-worksheets, with every design.

Estimated Flow- Class II – IV Dwellings

If flows estimates less than Type I are going to be used for design, water conservation is critical. Water conservation is defined by CIDWT as the management of water resources so as to eliminate waste or maximize efficiency utilizing such methods as using the same water again before it is wasted (becomes wastewater), installing water-efficient plumbing, or wastewater recycling and reuse. MN Rules Chapter 7080.1860 defines flow estimates for a variety of dwelling classifications.

Class II

A study on water use from the 1970's indicated that, on average, there was one more occupant in a house than the number of bedrooms. Using this information, the MPCA developed a reduced flow estimate for SSTS sizing if the dwellings contain 500 to 800 square feet per bedroom, when the dwelling's total finished floor area is divided by the number of bedrooms, and where no more than two of the water-use appliances listed in Classification I are installed or anticipated. The design flow for Classification II dwellings is determined by adding one to the number of bedrooms and multiplying this result by 75 gallons.

Class III

Classification III dwellings are those with less than 500 square feet per bedroom, when the dwelling's total finished floor area is divided by the number of bedrooms, and where no more than two of the water-use appliances listed in Classification I are installed or anticipated. The design flow for Classification III dwellings is determined by adding one to the number of bedrooms, multiplying this result by 38 gallons, then adding 66 gallons. These flow estimates are extremely conservative compared to more recent water use research (Mayer, 1999).

Class IV

A Class IV residence has no flush toilet, so the value for Class I, II, or III is reduced by 40 percent: flow x .6.

If a dwelling has a graywater system, it is a Class IV residence, and average daily flow is estimated as 60 percent of a similar house as shown in Table 5.2. Effluent from a graywater tank has to enter a soil treatment system for final treatment. It cannot be discharged to the surface. Proper sizing of the soil absorption system is based on Class IV flows and the appropriate soil hydraulic loading rate. See Section 7 for the discussion of the products available for the removal of the flush toilets from the source.

Measuring Flow for Design and Management

Flow measurement is any method used to accurately quantify the flow of liquid. **From MN Rules Chapter 7080.1100, Subp. 35, flow measurement means any method to accurately measure water or sewage flow, including, but not limited to, water meters, event counters, running time clocks, or electronically controlled dosing.** These methods are discussed below.

Water Meters

Septic systems are becoming more expensive both to install and to repair, so one goal is to design them to treat the actual amount of flow rather than an estimated amount, which may be high or low. Another goal is to get optimum use over the longest possible time from existing systems. In order to achieve these goals, it is helpful to know actual flow rates, which the water meter provides. While it is often necessary to use the values in Table 5.2 to estimate sewage flows, more accurate data should be obtained if possible. For example, if a chain restaurant is to be located beyond the reach of municipal

sewer, then data should be obtained from the parent company on water use rates of comparable facilities. A water meter can help ensure successful septic system operation.

To get keep track of the amount of water entering the septic system, include a water meter in the design of the system, or add one to an existing system.

All systems with pump and MSTs (MN Rules Chapter 7081.0230 D) must have a water meter installed, or they must have some other means of measuring flow - such as a running time clock or event counter on a pump.

Water meters come in many different shapes and sizes. Most water meters are designed to deal with clean water, which means that they may not function properly if they are used to measure the flow of sewage. For example, many water meters have small paddles or wheels that move to measure flow. These moving parts can be easily plugged by solids in sewage. One way to avoid this problem is to measure the flow of clean water before it is used in the house.

These meters should measure the water used inside the house, but not the water used outside for watering lawns and gardens, filling swimming pools, or washing cars, since this water does not enter the septic system. A filter to catch small particles should be installed to protect the water meter. Placing the meter after the water softener is common. If it's difficult to install a water meter so that it does not include the water to be used outdoors, try to estimate outside use, or use only data from December to March, when there is typically no outdoor use of water.

Installation

Water meters measure flow in either gallons per minute, gallons per hour, or cubic feet per second. Before doing any calculations using data from the meter, check to be sure of the units of measurement. Designs for septic systems typically use gallons per day. If the meter measures gallons per minute, multiply by 1,440 minutes per day. If it measures gallons per hour, multiply by 24 to get the gallons per day. If it measures cubic feet per second, multiply by 646,272 to convert to gallons per day. (See Table 5.4)

Meter Reading	Conversion Calculation	Converted Values
28 gallons per minute (gpm)	28 gpm x 1440	40,320 gpd
28 cubic feet (ft ³)	28 ft ³ x 7.5	210 gallons
28 cubic feet per second (ft ³ /s)	28 ft ³ /s x 646,272	323,126 gpd

The water meter should be installed by a plumber to make sure it is put in properly. Although it is installed directly into the water system, it will not affect water pressure.

Another type of clean water meter often found in houses is an on-demand water softener. These water softeners measure flow and recycle at certain set flow amounts. This system may also be used to calculate water flow. These calculations are not as straightforward as simply reading a meter and multiplying by a factor of 24 or 1,440, but this is a valid method of measuring clean water flow.

Event counter (cycle counter)

Another way to use a pump as a measurement device is to use an event counter. An event or cycle counter is a device used to record the number of times a component has been activated (e.g., activation of a pump followed by deactivation is one cycle). An event counter is a meter that records every instance of the pump turning on. By counting the number of times the pump turns on during a day you can measure the flow

5-24 ■ SECTION 5: Wastewater Sources and Flows

of wastewater going out to the system provided that you know from the septic system design how many gallons are to be pumped each time the pump turns on.

1. calculate the dose volume,
2. calculate the drainback,
3. calculate the net dose volume,
4. calculate the number of doses,
5. total flow is: Number of cycles x Net dose x Volume,
6. average flow is: Total flow ÷ Number of days.

This method is not as accurate as an elapsed time meter because the floats that turn the pump on have some variability. That is, the pump may turn on at six inches the first time and then 6-1/2 inches the second time. That can be a 15 to 20 gallon discrepancy each dose. If the event counter is turning five times a day, at a 20-gallon per time discrepancy, your calculations could be off by as much as 100 gallons of water that day. The number of cycles is critical for the drainback calculation.

Elapsed time meter (ETM)

All pumps run at a certain rate, so effluent flow can be calculated and calibrated from the pump system. This calibration can be done in the following steps:

1. calculate the gallons per inch
2. the level in the tank is measured,
3. the pump is run for a known amount of time (such as two timed minutes),
4. the amount of water that remains is measured,
5. the gallons is equal to inch drop multiplied by the gallons per inch,
6. the gallons removed is divided by the amount of time that the pump was running,
7. and a pumping rate in gallons per minute is the result.

Using this rate, the amount of water pumped can be calculated based on how long the pump has been running.

For example, assume you know that a tank contains 10 gallons per inch of water depth, and the depth of wastewater is three feet. (For information on determining the volume per unit depth of a tank, see Section 7). A pump is run for two minutes, and now the wastewater is measured as two feet deep. $36'' - 24'' = 12''$ of drop, $12'' \times 10 \text{ gpi} = 120$ gallons have been pumped in two minutes, so the rate = $120 \text{ gallons} \div 2 \text{ minutes} = 60$ gallons per minute (gpm). Now find out how many minutes the pump runs in the course of a day. If the same pump ran for a total of ten minutes, then during that day it pumped $10 \text{ min} \times 60 \text{ gpm}$ or 600 gallons. This is a quick way to use a pump and an ETM to calculate how much water is being used.

Once you know the pump's rate, check it regularly (annually at a minimum). The rate may slow to the point where it is not evenly distributing wastewater to the soil treatment system, or it may be failing. It is good to know before the pump stops working that there is a problem.

However it is measured, rate of flow is critical data that will allow the best design and operation of the septic system. Flow estimation is a great design tool. It allows for a

safety factor and peace of mind. Measured flow is used both to design systems and to verify performance. By using both flow figures appropriately, you give the system the best chance of good long-term performance.

Other Establishments and MSTs Hydraulic Determinations

There are three components when determining flow from a non-dwelling. The three components are dwellings, other establishments and infiltration from the collection system.

1. Dwellings

The design flow for MSTs serving existing dwellings is determined by the following calculation in conjunction with part 7080.1850: the total flow from the ten highest flow dwellings + (total flow from the remaining dwellings * 0.45) (7081.0120, Subp 2).

For new housing developments to be served by a common SSTS, the developer must determine and restrict the total number of bedrooms for the development. Proposed dwellings are determined to be Classification I dwellings for flow determination purposes unless different classifications are approved by the local unit of government. The determined classification system must be used in conjunction with the flow calculation method in subpart 1. If the ultimate development of phased or segmented growth meets or exceeds the thresholds in part 7081.0040, subpart 1, item B, the initial system or systems and all subsequent systems require a state disposal system permit (7081.0120, Subp 2).

The 0.45 multiplier are used due to less variability in flows and typically the number of residents averages out and the peaks flows are lower.

If construction of additional dwellings or bedrooms, installation of additional water-using devices, or other factors likely to increase the flow volumes can be reasonably anticipated, the MSTs must be designed to accommodate the additional capacity as determined by the local unit of government (7081.0120, Subp 3).

Per capita applicability

For systems that are operating, a less conservative estimate for actual use can be based on the people that are currently inhabiting the dwelling. For residential systems, an estimate between 50-75 gallons per person can be used for these flows. This is not a design flow but a check against the reading on the calculated flow. For example, in a four-bedroom Type I home, the design flow would be 600 gpd; however, when four people are actually living in the home, the real flow should be closer to $4 \times 50 \text{ gpd} = 200 \text{ gpd}$ to $4 \times 75 \text{ gpd} = 300 \text{ gpd}$. A measured flow of 500 gpd would point to higher risk due to high use or leaky fixture or components.

Even though size of a residence is used to estimate sewage flow, a sewage treatment system is designed for a certain number of gallons per day, not for a certain size of residence. For example, if a system is sized for 450 gallons a day (a Class I, three-bedroom home), and the home actually discharges an average of 600 or 700 gallons per day, hydraulic failure is likely to occur. The pretreatment unit will be overloaded, and each soil treatment unit has a finite capacity, which, if consistently exceeded, will lead to hydraulic overload of that system.

5-26 ■ SECTION 5: Wastewater Sources and Flows

Table 5.5 provides information on typical residential wastewater flows.

TABLE 5.5 Residential Wastewater Flows				
Study	Number of Residences	Study Duration (months)	Study Average (gal/person/day)	Study range (gal/person/day)
Brown & Caldwell (1984)	210		66.2 (250.6) ^a	57.3 – 73.0 (216.9 – 276.3) ^b
Anderson & Siegrist (1989)	90	3	70.8 (268.0)	65.9 – 75.6 (249.4 – 289.9)
Anderson, et al. (1983)	25	2	50.7 (191.9)	26.1 – 85.2 (98.9 – 322.5)
Mayer et al. (1999)	1188	1 ^c	69.3 (252.3)	57.1 – 83.5 (216.1 – 316.1)
DeOreo et al., (2016)	1000	1 ^c	58.6 (221.8)	
^a Based on indoor water use monitoring and not wastewater flow monitoring ^b Liters per person per day in parentheses ^c Based on two weeks of continuous monitoring in each of two seasons at each home (3) From US EPA <i>Onsite Wastewater Treatment Systems Manual</i> , EPA/625/R-00/008, US EPA Office of Water, 2002				

In addition to the daily flow variation, seasonal variations may also occur. Typically, wastewater treatment processes are sized to treat the maximum daily flow rather than simply having the capacity to treat the average daily flow. The maximum daily flow is the maximum flow that occurs over the course of a single day, perhaps 450 gallons per day for a typical 3-bedroom home. The average daily flow is the average of the flows that occur during single days over the course of some period of time – perhaps years. When evaluating measured flow 70% of the Design Flow should be considered normal. Values higher would be considered riskier in their applications. For example a Design Flow of 600gpd should average less than 420gpd: $600 \times 70\% (0.7) = 420\text{gpd}$.

2. Other Establishments

According to MN Rules Chapter 7081.0130 design flows for other establishments are determined by methods A (flow estimates as shown in Table 5.6) or B (using measured flow from a seven-day period in which the establishment is at maximum capacity or use).

TABLE 5.6 Estimated Design Sewage Flow from Other Establishments		
Dwelling units (also see outdoor recreation)	Unit	Design flow (gal/ day/unit)
Hotel or luxury hotel	guest	55
	square foot	0.28
Motel	guest	38
	square foot	0.33
Rooming house	resident	45
	add for each nonresident meal	3.3
Daycare (no meals)	child	19
Daycare (with meals)	child	23
Dormitory	person	43
Labor camp	person	18
Labor camp, semipermanent	employee	50

SECTION 5: Wastewater Sources and Flows ■ 5-27

TABLE 5.6 Estimated Design Sewage Flow from Other Establishments (cont'd)

Commercial/Industrial	Unit	Design flow (gal/ day/unit)
Retail store	square foot	0.13
	customer	3.8
	toilet	590
Shopping center	employee	11.5
	square foot	0.15
	parking space	2.5
Office	employee/8-hour shift	18
	square foot	0.18
Medical office*	square foot	1.1
	practitioner	275
	patient	8
Industrial building*	employee/8-hour shift	17.5
	employee/8-hour shift with showers	25
Laundromat	machine	635
	load	52.5
	square foot	2.6
Barber shop*	chair	68
Beauty salon*	station	285
Flea market	nonfood vendor/space	15
	limited food vendor/space	25
	with food vendor/space	50
Eating and drinking establishments	Unit	Design flow (gal/ day/unit)
Restaurant (does not include bar or lounge)	meal without alcoholic drinks	3.5
	meal with alcoholic drinks	8
	seat (open 16 hours or less)	30
	seat (open more than 16 hours)	50
	seat (open 16 hours or less, single service articles)	20
	seat (open more than 16 hours, single service articles)	35
Restaurant (short order)	customer	7
Restaurant (drive-in)	car space	30
Restaurant (carry out, including caterers)	square foot	0.5
Institutional meals	meal	5.0
Food outlet	square foot	0.2
Dining hall	meal	8.5
Coffee shop	customer	7
Cafeteria	customer	2.5
Bar or lounge (no meals)	customer	4.5
	seat	36
Entertainment establishments	Unit	Design flow (gal/ day/unit)
Drive-in theater	car stall	5
Theater/auditorium	seat	4.5
Bowling alley	alley	185
Country club	member (no meals)	22
	member (with meals and showers)	118
	member (resident)	86
Fairground and other similar gatherings	visitor	1.5
Stadium	seat	5
Dance hall	person	6
Health club/gym	member	35

5-28 ■ SECTION 5: Wastewater Sources and Flows

TABLE 5.6 Estimated Design Sewage Flow from Other Establishments (cont'd)

Outdoor recreation and related lodging facilities	Unit	Design flow (gal/ day/unit)
Campground	person with hook-up	32
	site with hook-up	100
	site without hook-up, with central bath	50
	site to be served by dump station	63
Permanent mobile home	mobile home	225
Camp, day without meals	person	20
Camp, day with meals	person	25
Camp, day and night with meals	person	45
Resort/lodge hotel	person	62
Cabin, resort	person	50
Retail resort store	customer	4
Park or swimming pool	guest	10
Visitor center	visitor	13
Transportation	Unit	Design flow (gal/ day/unit)
Gas station/convenience store	customer	3.5
Service station*	customer	11
	service bay	50
	toilet	250
	square foot	0.25
Car wash* (does not include car wash water)	square foot	5
Airport, bus station, rail depot	passenger	5
	square foot	5
	restroom	565
Miscellaneous	Unit	Design flow (gal/ day/unit)
Public lavatory	user	5
Public shower	shower taken	11
Institutional	Unit	Design flow (gal/ day/unit)
Hospital*	bed	220
Mental health hospital*	bed	147
Prison or jail	inmate	140
Nursing home, other adult congregate living	resident	125
Other public institution	person	105
School (no gym, no cafeteria, and no showers)	student	14
School (with cafeteria, no gym and no showers)	student	18
School (with cafeteria, gym, and showers)	student	27.5
School (boarding)	student	95
Church	seat	4
	add for each meal prepared	5
Assembly hall	seat	4

* Waste other than sewage is only allowed to be discharged into the system if the waste is suitable to be discharged to groundwater.

Unless otherwise noted in Table 5.6, **the flow values do not include flows generated by employees. A flow value of 15 gallons per employee per eight-hour shift must be added to the flow amount. Design flow determination for establishments not listed in Table 5.6 shall be determined by the best available information and approved by the local unit of government (7081.0130 Subp 1 A).**

For these establishments the waste concentration of the effluent needs to be considered if concentrations of biochemical oxygen demands, total suspended solids, and oil and grease from the sewage are expected to be higher than 170 mg/L (or 125 mg/L CBOD₅), 60 mg/L, or 25 mg/L respectively. **An estimated or measured average concentration must be determined and be acceptable to the local unit of government. System design must account for concentrations of these constituents so as not to cause internal system malfunction, such as, but not limited to, clogging of pipes, orifices, treatment devices, or media (7081.0130, Subp. 2).**

Measured Flow

From 7081.0130, Subp. 1(B) the measured design flow of sewage for MSTs serving other establishments is determined by averaging the measured daily flows for a consecutive seven-day period in which the establishment is at maximum capacity or use.

To calculate the measured design flow, you will need two sets of data:

1. daily flow data, and
2. capacity of the establishment for each day.

A minimum of 90 days of flow during the busiest time of the year is the minimum recommended amount of data, but one full year of data is recommended (the more data you have, the greater the confidence you will have). The worksheet “Measured Flow: Other Establishments” provides a location to calculate these values. This can be found at septic.umn.edu/ssts-professionals/forms-worksheets.

Daily flow should be in gallons per day (gpd). Some water meters give cumulative readings (so that one day the meter may measure 400 gallons, the next day 850 gallons, and the next day 1,200 gallons). If this is the case, make sure to convert the gallons into a per-day unit. In this example, 400 gallons are discharged on day 1; $850 - 400 = 450$ gallons for day 2; and $1200 - 850 = 350$ gallons for day 3. Make sure you are using the correct units when you use the information to design a system (see Table 5.4).

Some meters measure cubic feet of water in the meter. Be careful that you convert these values to gallons before completing the calculations. Capacity of the other establishment should be in the form of percentage full or percentage use. For example, a typical campground may estimate that 60 percent of its campground sites are in use. Remember that percentage is converted to a decimal format by dividing by 100. ($60\% \div 100 = 0.60$)

Organize the data by day number, date, flow, and capacity, with additional columns for measured maximum design flow and measured average design flow.

The measured maximum design flow is calculated assuming the facility is at 100 percent capacity; therefore, the daily flows need to be converted to design flows by using the percentage capacity on that day. Calculate the measured design flow by dividing the percent capacity into the daily flow rate. Let’s say for day 1 the flow meter reads 2,000 gal and the business is 60% full. The measured flow is calculated as $2,000 \div 0.60 = 3,333$

5-30 ■ SECTION 5: Wastewater Sources and Flows

gpd. Calculate the measured maximum design flow for each day at 100 percent capacity for each day.

Measured design flow is calculated assuming the facility is at 100 percent capacity; therefore, the converted flows are used. To calculate measured average design flow, average the seven highest consecutive flows at 100 percent capacity. Calculate the average from days 1-7 (2,000 gpd, 2,100 gpd, 2,600 gpd), then days 2-8, then days 3-9, etc. Select the highest value.

Design Process for Determining Flow

The worksheet “Final Flow Total” should be completed with the following information:

1. Calculate flows from dwellings, enter into number 1.
2. Calculate flows from other establishments:
 - a. If existing establishment: install flow measuring device if one is not present, collect daily flow data during the time of peak facility use. A minimum of 90 days is recommended. Calculate flow characteristics from measured flow data (worksheet “Measured Flow: Other Establishments”).
 - b. Use Table 5.6 (7081.0130) to determine estimated flow. This value must be used for permitting purposes. If measured flow data is not available this value will also be used for design flow.
 - c. Compare calculated flow to measured flow data. Based on best professional judgment on consultation with facility owner regarding current and future use provide documentation and LGU enter the appropriate value into number 2.
3. Add in I & I under number 3. According to MN Rules Chapter 7081.0140, the design flow must also include 200 gallons of infiltration and inflow per inch of collection pipe diameter per mile per day with a minimum pipe diameter of two inches to be used for the calculation. Flow values are allowed to be further increased if the system employs treatment devices that are exposed to atmospheric conditions that will infiltrate precipitation. Flow estimates as calculated in this chapter shall not be relied upon for the design of collection systems.
4. Refer to code and design guidance and consult with LGU as to required design flow rate for various components in the system include grease traps, septic tanks, surge tanks, pretreatment unit and soil treatment area.
5. It is recommended that the operating permit have a mitigation trigger at 70% of design flow.

This form can be found at septic.umn.edu/ssts-professionals/forms-worksheets.

Design best-practices checklist

- Be sure to check with the local government unit before any changes are made to the onsite system.
- Route your furnace, water softener and iron filter discharge out of the onsite system.
- This water can be day-lighted to the surface as long as it does not directly discharge into a water body. Alternatively, it can go into an existing drywell or abandoned drain field. If it is day-lighted, remember that this water contains salt

and can be hard on vegetation. Freezing can be a concern for day-lighted water in winter.

- Install a small separate section of drainfield to deal with this water (no tank is needed). In most cases 20-50 feet² should be sufficient.
- If only the furnace water is being added, this can go into the onsite system, but a sump or other device to collect the water must be used so water is not trickling out, causing freezing problems.
- If rerouting is not an option, a good solution for everyone is to minimize the amount of salt and water used by the softener or iron filter.
- Reduce the total volume of water used in the home.
- Adjust the water softener or iron filter to recharge less frequently. Adjusting the frequency can be done by lengthening the time between recharges on a timed unit or increasing the volume of water passing through the unit before recharging on a metered unit.

3. Infiltration from the Collection System

According to MN Rules Chapter 7081.0140, the design flow must also include 200 gallons of infiltration and inflow per inch of collection pipe diameter per mile per day with a minimum pipe diameter of two inches to be used for the calculation. Flow values are allowed to be further increased if the system employs treatment devices that are exposed to atmospheric conditions that will infiltrate precipitation. Flow estimates as calculated in this chapter shall not be relied upon for the design of collection systems.

Waste Characteristics: Waste Strength Components

Components of Wastewater

Effluent quality is the physical, biological, and chemical characteristics of a liquid flowing from a component or device. The components of wastewater may be divided into four categories:

- biochemical oxygen demand, total suspended solids and fats, oils and grease (BOD₅, TSS, FOG),
- pathogens (fecal coliform, viruses),
- nutrients (nitrogen, phosphorus), and
- other chemicals.

Table 5.7 shows typical concentrations of these components in raw waste, septic tank effluent, and soil. The waste strength of sewage and effluent as it passes through a treatment system can indicate the performance of a septic system. Understanding how these components enter the waste stream and are removed through the treatment process is critical for system designers and service providers. This section will describe these wastewater components.

TABLE 5.7 Unsaturated Flow During Soil Treatment of Septic Tank Effluent

Parameter	Raw Waste	Septic Tank Effluent	One Foot Below Distribution Media	Three Feet Below Distribution Media
BOD ₅ (mg/L)	30-1147***	39-861***	0**	0**
TSS (mg/L)	18-2233***	22-276***	0**	0**
Fecal Coliform (MPN/100ml)	30,000-10,000,000,000**,***	1,000-120,000,000**,***	1-100**	0**
Viruses (PFU/ml)	unknown**	100,000-10,000,000**	0-1,000**	0**
Nitrogen (mg/L)				
Total	35-189**,*	25-124**,*	—	—
TKN	7-40**	20-60**	*B-20**	—
NO ₃	<1**	<1**	*B-40**	*B-40**
Total Phosphorus (mg/L)	10-27**	3-40***	*B-10**	*B-1**
* B = background ** Tchobanoglous and Burton, 1991 *** Lowe et al., 2007				

Waste Strength

Residential strength effluent is defined as septic tank effluent or other treatment device with a BOD₅ less than or equal to 170 mg/L; TSS less than or equal to 60 mg/L; and fats, oils, and grease less than or equal to 25 mg/L (7081.0130, Subp 2).

High-strength wastewater is defined as:

1. influent having BOD₅ greater than 300 mg/L; and/or TSS greater than 200 mg/L; and/or fats, oils, and grease greater than 50 mg/L entering a pretreatment component (as defined by NSF Standard 40 testing protocol);
2. effluent from a septic tank or other pretreatment component that has BOD₅ greater than 170 mg/L; and/or TSS greater than 60 mg/L; and/or fats, oils, and grease greater than 25 mg/L and is applied to an infiltrative surface.

Biochemical Oxygen Demands (BOD₅), Dissolved Oxygen, and Total Suspended Solids (TSS)

Biochemical oxygen demand (BOD₅) is the most widely used parameter applied to wastewater. BOD₅ is a measure of the dissolved oxygen required by microorganisms to oxidize or decompose the organic matter in wastewater. A typical BOD₅ value for septic tank effluent is 150 milligrams per liter. For a Type I system, the BOD₅ limit is 170 milligrams per liter.

When the dissolved oxygen (DO) contained in septic tank effluent is measured, it is usually very low, typically one milligram per liter. While DO in water can be as high as 12 milligrams per liter, the microorganisms in the septic tank normally use up any available oxygen to break down organic matter.

Total suspended solids (TSS) is a measure of the solids that remain in the wastewater after settling has occurred in the tank. A typical TSS value is 60 milligrams per liter. BOD and total suspended solids together measure the strength of the wastewater. They

SECTION 5: Wastewater Sources and Flows ■ 5-33

can serve as an indicator of system performance. Table 5.8 identifies estimated BOD for other establishments. The data is taken from a CIDWT Publication entitled, Analyzing Wastewater Treatment Systems Serving Residential and Commercial Facilities for High Strength and Hydraulic Loading, 2008. You can calculate the estimated concentration of BOD₅ by using the following equation:

$$\text{Concentration (mg/L)} = \# \text{ lbs BOD}_5 \div Q(\text{gpd}) \div 8.35 \times 1,000,000$$

TABLE 5.8 Estimate of Waste Strengths from Other Establishments	
Type of Facility	BOD (lbs/unit/day)
Airports	
Per passenger	0.02
Per employee	0.05
Apartment houses– multiple family	0.175/unit
Boarding houses	0.14/person
Bowling alley (no kitchen)	0.15/lane
Camps	
Construction (Semi-permanent)	0.140/person
Day (no meals)	0.031/person
Luxury	0.208/person
Resort - night & day/limited plumbing	0.140/person
Church (no kitchen)	0.02/seat
Country club	0.208/member
Dwelling– single family	0.17/person
Employee/personnel addition	0.04/employee
Factory	
No showers	0.073/employee
With showers	0.083/employee
Hospital	0.518/bed
Hotel	0.125 per room/ two person
Mobile home park	0.140/person
Motel	
per bed space	0.083/bed
Per room w/ bath, toilet & kitchen wastes	0.14/person
Nursing home	0.26/person
Office building (no food)	0.05/employee
Park	
toilet wastes only	0.01/person
bathhouses, showers and flush toilets	0.021/person
Restaurant	
Kitchen waste	0.015/meal
Toilet and kitchen waste	0.021/customer
Additional for bars and cocktail lounges	0.01/customer
School, day	0.031/student
Add for gym/showers	0.011/student
Add for cafeteria	0.011/student
School, boarding	0.208/student
Service station	0.021/vehicle served
Shopping center (no food service or laundry)	0.050/employee
Sports stadiums	0.20/person
Stores	0.832/toilet room
Swimming pools and bathhouses	0.021/person
Theaters	
Drive-in	0.010/car space
Indoor	0.010/seat
Trailer Park	0.35/trailer

Types of BOD

Biochemical Oxygen Demand

BOD or Biochemical Oxygen Demand is the quantity of dissolved oxygen consumed by microorganisms during the microbial and chemical oxidation of the constituents contained in a wastewater sample during an incubation period at a given temperature. The biochemical oxygen demand represents the oxygen utilized during the oxidation of both carbon and nitrogenous compounds.

Biochemical Oxygen Demand (BOD₅)

BOD₅ or Biochemical Oxygen Demand – 5-day is the quantity of dissolved oxygen consumed by microorganisms during the breakdown of organic matter in a wastewater sample during a 5-day incubation period and measured in mg/L at 20°C. It is used as a means to describe the amount of organic matter present in the water.

Biodegradable organic matter is provided in terms of pounds of BOD₅ per person (capita) per day by using the BOD₅ concentration and daily flow. Biochemical oxygen demand is a measure of the oxygen required by bacteria, chemicals, and other organisms to break down organic matter over a five day period. It is an indicator of the overall strength of the wastewater. Most designs assume that all residential sources generate a concentration of 300 mg/L of BOD₅, and after pretreatment in a properly sized septic tank the BOD₅ is reduced to approximately 170 mg/L (Table 5.7). However, these concentrations can vary from site to site.

Carbonaceous Biochemical Oxygen Demand (CBOD)

CBOD or Carbonaceous Biochemical Oxygen Demand is the quantity of dissolved oxygen consumed by microorganisms during the breakdown of organic carbon in a wastewater sample during an incubation period of 5 days at 20°C. An inhibitor is placed in the sample to prevent growth of nitrogenous oxidizing microbial populations. It is used as a means to describe the amount of organic carbon present in the water that can be broken down with microbial processes.

Nitrogenous Biochemical Oxygen Demand (NBOD)

NBOD or Nitrogenous Biochemical Oxygen Demand is the quantity of dissolved oxygen consumed by microorganisms during the oxidation of nitrogenous compounds such as protein and ammonium in a wastewater sample during an incubation period of 5 days at 20°C. It is used as a means to describe the amount of organic nitrogen (such as urea, proteins, etc.) present in the water. It is not usually used in typical wastewater analysis.

Ultimate Biochemical Oxygen Demand (UBOD)

Ultimate Biochemical Oxygen Demand is the measure of the oxygen required to complete the breakdown of the organic matter. The UBOD consists of summing the oxygen demand required to oxidize the organic matter in the wastewater, synthesize the organic matter into new cell tissue, and the endogenous respiration where cell tissue is consumed by other microbes to obtain energy for cell maintenance. The UBOD is not typically a value measured in lab analysis.

Source and Impact of BOD₅ on Systems

High BOD₅ levels are caused by high organic loading to the system. In a residential system, the number of people in the house could be greater than that for which the system was designed and originally constructed. In this situation it is also possible that the concentration might not be elevated, but the overall organic mass loading could be significantly higher. An elevated BOD₅ concentration could also be influenced by the activities that are happening at the source. In homes or restaurants, the presence of a garbage disposal, the types of foods prepared and methods to prepare them can increase the BOD₅ levels. In a home, a large portion of BOD₅ is produced from toilet water. Toilet water also produces a large part of the natural microorganisms. A high BOD₅ (> 170 mg/L) can cause the growth of excessive biomass that can clog and shorten the lifespan of the soil treatment area.

High BOD₅ in the effluent moving to the downstream components of the treatment train could also be caused by a broken inlet or outlet baffle in the septic tank, infrequent tank maintenance, or reduced biological activity in the septic tank. BOD₅ levels are roughly cut in half in a properly operating septic tank (Magdorf, 1974). Baffles manage the flow of sewage to facilitate settling and anaerobic decomposition. BOD₅ reduction is limited if baffles are not operational. Appropriately removing accumulated scum and sludge from the tank also facilitates the proper operation of a septic tank. Chemicals used by the source may play a large role in inhibiting the reduction of the BOD₅, therefore causing a high effluent BOD₅ concentration. Onsite wastewater treatment systems use naturally existing microorganisms to reduce the contaminants and treat wastewater. During treatment, the microorganisms feed on constituents in the wastewater, reducing their concentration and resulting in cleaner wastewater. Harsh chemicals, such as bleach, detergents, cleaners, and disinfectants, can kill these microorganisms and reduce their ability to breakdown contaminants such as BOD₅.

Low BOD₅ from a home may be due to a low occupancy or a low number of meals prepared at home. A low BOD₅ concentration may also be created through dilution from higher than normal hydraulic flows into the wastewater treatment system. This dilution effect could be due to the extra use of appliances, such as laundry machines, Jacuzzis, or long showers. Leaking fixtures can also add extra water. If clear water sources such as water treatment systems or condensate drains are plumbed into the system, the increase in carriage water volume will dilute the constituents in the wastewater and decrease the concentration of food supply. Commercial systems may have a low BOD₅ if a low percentage of the wastewater comes from the bathroom and the rest comes from sources with low BOD₅ contributions with significant carriage water volume.

In typical wastewater treatment trains, your senses may assist in estimating relative BOD₅ concentrations. You can recognize BOD₅ levels that are not average by the clarity of the water. Clear water is an indication of a low BOD₅ level. The cloudier the wastewater is, the higher the organic loading. This assumes suspended clays are not part of the waste stream. If the wastewater odor is sour and rancid or if it smells like a detergent or a cleaner, this may be a sign that chemicals are present that can inhibit biological treatment, resulting in a high BOD₅.

Chemical Oxygen Demand (COD)

Chemical Oxygen Demand (COD) is a measure of the amount of organic matter oxidized by a strong chemical oxidant. COD is used to measure organic matter in com-

mercial, industrial, and municipal wastes that contain compounds toxic to biological life where the BOD₅ test would not work. The COD levels in a wastewater sample are almost always greater than BOD₅ levels because more compounds can be chemically oxidized in the COD test than can be biologically oxidized in the BOD test. In most cases, once the COD/BOD₅ relationship is known for a particular facility, the COD concentration of a sample can be used to approximate the BOD₅ concentration. The COD test can generally be done within 2.5 hours, whereas a BOD₅ test takes five days. A COD test is performed when a quick determination of oxygen demand is needed.

Total Suspended Solids (TSS)

Total suspended solids or TSS is the most common measure of the amount of solids in wastewater effluent. TSS is the measure of all suspended solids in a liquid, typically expressed in mg/L. It is measured by filtering a well-mixed sample through a standard glass fiber filter and drying the residue retained on the filter at 217 to 221 degrees F (103 to 105 degrees C). The increase in the weight of the filter represents the amount of total suspended solids.

Other terms and measurements of solids in wastewater treatment systems are:

- Solids, settleable: suspended solids that will settle out of suspension within a specified period of time, expressed in milliliters per liter (mL/L)
- Solids, total (TS): mineral, cells, etc. left in wastewater after evaporation of the water fraction at 103 degrees C, typically expressed in mg/L
- Solids, total dissolved (TDS): material that passes a standard glass fiber filter, and remains after evaporation at 103 degrees C, typically expressed in mg/L
- Solids, volatile: weight loss on ignition of total solids, not distinguishing between inorganic and organic matter and including loss due to decomposition or volatilization of some mineral salts at 550 degrees C

TSS and BOD₅ are typically the two parameters used to measure wastewater strength and treatment performance relating to organic/inorganic matter. TSS (as stated earlier) is measured by performing a solids analysis but can also be estimated by a turbidity test. Turbidity is the physical clarity of the water and is an indicator of the presence of suspended matter in wastewater. A “quick and dirty” TSS test can be determined with an Imhoff Cone. A visual test will determine if TSS levels are high or low when a sample of wastewater is placed in a cone against a light background.

Impact of TSS on systems

High TSS can place a great demand on the downstream devices and could lead to clogged components and orifices in distribution manifolds. High TSS can result from:

- The system being under-designed for the source supply
- Use of low flow fixtures—although they conserve water, they do not reduce the constituent mass loading and result in higher concentrations
- Use of a garbage disposal
- Kitchen practices—e.g., kitchen clean-up, food preparation, or cuisine
- Above average use of toilet paper, which can be broken down biologically but only by fungus, which needs air to function. Microbes present in septic tanks typically do not break down paper products which are wood-based
- Laundry machines—due to clothing fibers, clay, or soils present on the clothes

The volume of dirt or grime present in the laundry will directly relate to the habits, hobbies, and occupation of the residents.

Although low TSS is not a problem for the system, it could indicate that something else is wrong with the system. Low TSS could be due to:

- Fewer users on the system than considered in the original design
- Higher flows from low TSS sources
- Clear water inflows

Fats, Oils and Grease (FOG)

FOG (fats, oils, and grease) is a constituent of sewage typically originating from food stuffs (animal fats or vegetable oils) or consisting of compounds of alcohol or glycerol with fatty acids (soaps and lotions), typically measured in mg/L.

Sources of FOG

Fat found in onsite wastewater treatment systems is animal fat, oil is from vegetable and cooking oils, and grease is from petroleum based soaps. FOG are generally treated in onsite wastewater treatment systems by separating them from the wastewater stream. At high temperatures FOG are in a liquid state, but as the temperature cools, the fats component will solidify (Table 5.9). FOG can be trapped in pretreatment components, such as septic tanks and grease traps, where they typically float to the top of tanks. They are less dense and lighter than water. It is important to try to contain FOG early in the system, because they can accumulate inside pipes and lead to clogging of downstream components. FOG also contribute to BOD₅ and TSS concentrations. FOG in excessive amounts interfere with aerobic biological processes and lead to decreased treatment efficiency. The expected levels of FOG concentration must be considered during wastewater treatment design.

TABLE 5.9 Characteristics of fats, oils and grease in wastewater.

Constituent	State at Room Temperature ¹	Derived From	Comments ²
Fats	Solid	Animal fat	Non-toxic to the system
Oils	Liquid	Vegetable and cooking oils	Non-toxic to the system
Grease	Liquid	Petroleum based products: soaps, hair conditioners, tanning oils, oil/grease on hands/clothes, bath oils, etc.	Residual material on appliances; solid material attached to pans/equipment; may potentially be toxic to microbes commonly present in the wastewater treatment system.

¹ Room temperature assumes 80°F.
² Warning: the use of a degreaser will move all of these components through the wastewater system

FOG in domestic wastewater will generally originate in the kitchen or bathroom. Kitchen FOG usually come from disposing animal- or vegetable-based food scraps and liquids down the sink. Households using garbage disposals will have 30-40 percent more FOG than households not using garbage disposals. Bath oils, sun tan lotions, hair conditioners, and moisturizing creams are bathroom sources of FOG that enter the wastewater stream. An increased use in cooking oils, lotions, and hair conditioners will directly increase the FOG concentration in the wastewater.

Low FOG, although it is not considered a problem, could be the result of not using the kitchen or of higher than normal flows entering the system. Low FOG can also be attributed to the use of bar soap instead of liquid soaps.

Impact of FOG on systems

Fat

Animal fat is relatively easy to hold in a tank because it's quite sensitive to temperature. It becomes a solid at 80°F, and wastewater temperature is usually less than 80°F. Animal fat will break down in the soil, but it takes four times more energy to break down than the organic matter typically measured by BOD₅. Fat is added to the system from cooking, clean up, and dish washing, so commercial systems will typically have higher levels of fat than residential systems. If a system is supplied with a lot of animal fat, it will typically stay in the septic tank. If it is contained in the septic tank, it may not be observed in FOG measurements in downstream components.

Oils

Vegetable oil is not as sensitive to temperature as fat and can pass through the system. Oil can also be broken down through a biological process, but it takes 12 times more energy to break down oil than the organic matter typically measured by BOD₅. There are many different types of oils used, but vegetable is the most common. Vegetable oil is often used in the liquid form, but it can also be solid shortening. The liquid form is harder to hold in a tank. Table 5.10 lists several different types of fats and oils that are commonly used and lists their physical properties.

Substance	Melting Point (°F)	Density (g/mL) @ 59-68 (°F)
Corn Oil	12	0.923
Olive Oil	32	0.918
Vegetable Oil	n/a	0.910
Canola Oil	14	0.92
Soy-bean Oil	3.2	0.92
Sunflower Oil	2	0.919
Cottonseed Oil	55	0.926
Shortening	115	n/a
Lard (Fat)	86	0.919

The ability of the oil to separate is influenced not only by temperature, but also by how the oil was generated and used. Free oil will rise to the wastewater surface and be easily separated when the mixture is allowed to become quiescent. Emulsified oil has been broken up into very small droplets and occurs either by mechanical or chemical action. An example of mechanical emulsification is when extremely hot water from a dishwasher is mixed with the oil. Given time and a decrease in temperature, this oil can be separated. Chemical emulsification occurs when detergents or cleaners produce a mix of oil and water. Degreasing compounds can generate dissolved oils, in which discrete oil particles are no longer present. Chemically emulsified oil will take a longer time to separate, increasing the risk of carrying it to downstream components unless long quiescent periods are available to allow separation.

Grease

Grease is petroleum-based and can be toxic to a system. Because grease is petroleum-based, it cannot be broken down, but it can be separated. Grease comes from lotions, hair products, and soaps. Typically, there will be a higher percentage of grease in the FOG from residential systems when compared to most commercial systems. Grease can build up over time, coating components and inhibiting treatment of other constituents in the wastewater.

Design Process for HSW

- a. Evaluate reference documents for potential of generating HSW.
- b. Evaluate other establishment sources using Facility Use Survey.
- c. Sample effluent from the existing system, if possible.
 - i. **When.** The system should be sampled within 18 hours of known peak usage. It is optimum if the tank is not in need of pumping (worst case) and not pumped recently (best case) to get a representative sample.
 - ii. **Where.** It is best to sample from the outlet of the last septic tank or pump tank (best location).
 - iii. **How.** Samples can be either pumped from the wastewater surface inside the baffle of the tank or a bottle can be lowered into the gap taking the sample as near to the wastewater surface as possible. The sides of the baffle should be avoided so that the FOG buildup on the baffle wall is not added into the sample. If a sample is taken from a pump tank, take it from the dose volume, be sure to move aside a scum layer or sludge layer if it exists.
- d. Either with estimates or measurements determine if the design must account for high strength wastewater.
- e. Calculate the projected loading to the downstream components in lbs of BOD₅ per day. Pounds = Concentration x Flow x 8.35 ÷ 1,000,000

Biological Treatment Processes

Wastewater Oxygen States

To fully understand the biological treatment process the oxidation states in a system are critical. Oxidation is:

1. the chemical reaction in which a loss of electrons results in an increase in oxidation number (valence) of an element; occurs concurrently with reduction of the associated reactant;
2. the chemical or biological conversion of organic matter to simpler, more stable forms in the presence of oxygen with a concurrent release of energy and
3. the process of a substance combining with oxygen.

These treatment process can either occur under aerobic, anaerobic or anoxic conditions.

1. **Aerobic:** having molecular oxygen (O₂) as a part of the environment, or a biological process that occurs only in the presence of molecular oxygen. Typically aerobic

bacteria dominate in this environment and metabolize only in the presence of molecular oxygen.

2. Anaerobic: absence of molecular oxygen (O_2) as a part of the environment, or a biological process that occurs in the absence of molecular oxygen; bound oxygen is present in other molecules, such as nitrate (NO_3^-) sulfate (SO_4^{2-}) and carbon dioxide CO_2 . Anaerobic bacteria dominate in this state because they are able to metabolize in the absence of molecular oxygen.
3. Anoxic: condition in which all constituents are in their reduced form (no oxidants present); conditions in a septic tank are generally anaerobic, but not anoxic; see also aerobic and anaerobic.

Biological processes for treatment take many different forms, including die-off, predation, oxidation, and mineralization. Natural die-off occurs when pathogens are held in nutrient-poor aerobic conditions. Predation occurs when microorganisms attack and destroy pathogenic bacteria and viruses. Biological oxidation occurs when bacteria break down organic matter into water and carbon dioxide (CO_2). Oxidation reduces BOD_5 , removes pathogens, and works best under aerobic conditions. Mineralization transforms organic nitrogen into inorganic forms of nitrogen that can become part of other biologically driven treatment processes, such as nitrification and denitrification.

The microbes that are used for biological treatment require food (which is the constituents in the wastewater) and an environment consisting of optimal conditions. The following parameters can influence the effectiveness of treatment by influencing the performance of the microbes:

- Dissolved oxygen (DO)
- pH
- Temperature

These parameters are used as indicators for the presence of other constituents in the wastewater. If one of these parameters is not in the expected range, then it can be assumed that the wastewater is not being properly treated, because the microbes cannot function properly. All of these parameters can be evaluated in the field. If one of them is out of the expected range, lab tests evaluating other constituents and system performance should be run.


Dissolved Oxygen (DO)

Dissolved Oxygen (DO) is the amount of oxygen dissolved in water. It is influenced mainly by temperature, barometric pressure (altitude), and water salinity. As temperature decreases, the amount of dissolved oxygen that can be accepted by water increases until it becomes saturated.

The three oxygen states are aerobic, anaerobic, and anoxic conditions. The term aerobic is defined as having molecular oxygen (free oxygen, O_2) as a part of the environment or a biological process that occurs only in the presence of molecular oxygen. An anaerobic condition is the absence of molecular oxygen as a part of the environment or a biological process that occurs in the absence of molecular oxygen but can utilize oxygen bound in other molecules, such as nitrate (NO_3^-). Anoxic is the condition in which all wastewater and/or effluent constituents are in their reduced form, meaning there are no oxidants present.

The microorganisms (bugs) that are used for biological treatment can be categorized by the state of oxidation in which they operate. These categories of microorganisms include:

- Aerobes – thrive in aerobic conditions
- Anaerobes – thrive in anaerobic conditions
- Facultative – thrive in both aerobic and anaerobic conditions



Free oxygen (O_2) is needed for aerobic treatment to take place, and aerobic bacteria need oxygen to grow and live. Aerobic organisms respire dissolved oxygen contained in the water. Anaerobic bacteria grow and live in the absence of free oxygen. Facultative organisms have the ability to respire free oxygen when it is available and shut down the respiration process when dissolved oxygen is lacking. Table 5.11 gives the desired ranges of DO in wastewater.

Anaerobic bacteria are significantly slower at oxidation and smaller in size than aerobic bacteria (Figure 5.3), but they are much more resilient to environmental changes. Aerobic microorganisms are more sensitive to wastewater parameters (such as DO, pH and temperature), but in optimal conditions, they digest organic matter and pathogens more rapidly than do anaerobic organisms.

TABLE 5.11 Ideal Dissolved Oxygen Range in Wastewater

Microbes	Anaerobe	Facultative	Aerobe
Low DO (mg/L)	0	0	0.5
High DO (mg/L)	0.5	5	5
Typical (mg/L)	0-0.3	0-1	1-3

The septic tank is typically considered an anaerobic treatment component, although there can be aerobic zones. For the most part, septic tank microbes assimilate the waste constituents in the absence of a respiration process and are commonly referred to as anaerobic microbes. Facultative microbes utilize free oxygen or assimilate waste without respiration. During assimilation of waste, the bonds holding the oxygen are broken and allow the compounds to react with other components (i.e., SO_4^- , H_2S). Therefore, septic tanks can have both anaerobic and facultative bacteria treating the wastewater.

The anaerobic bacteria do not thrive in environments with free oxygen. Water entering the septic tank has dissolved free oxygen which must be removed by the oxygen requirements of the wastewater so the anaerobic bacteria can survive. As the system matures, the anaerobic bacteria become more efficient. The oxygen demand in the system rapidly removes free oxygen entering with the influent and maintains the anaerobic environment. The greater removal rates of BOD and TSS are achieved under this fully anaerobic environment.

If the water source has low DO, then the amount of DO entering the onsite wastewater treatment system will be low. Low DO in the wastewater could also be caused by a high organic load. In aerobic treatment processes, high concentrations of BOD_5 , FOG, and nutrients will exhaust the oxygen in the wastewater. This is because the microbes present in the system require more oxygen to break down the increase in food.

5-42 ■ SECTION 5: Wastewater Sources and Flows

High DO can be attributed to the water source and/or dilution due to leaking fixtures or infiltration. Also, if there is a significant amount of dead microbes in the system due to a chemical upset, a high DO may result. The microbes are not robust and are not depleting the oxygen supply.

Although high or low DO is not a contaminant, it can be used as an indicator. Low DO is expected in the septic tank, but should be greater than 1.0 mg/L in the aeration component. Be cautious when sampling for DO not to add oxygen. In addition, the sampling method may be faulty and give inaccurate readings.

pH

pH is a term used to describe the relative amount of acidity or basicity in the wastewater. Low pH values indicate a high concentration of hydrogen ions (acids) in solution, and high pH values indicate a low concentration of hydrogen ions (basic). The pH value can range from 1 to 14 with a value of 7 being neutral. The ideal pH in wastewater will typically be around the neutral range (Table 5.12).

Ideal Range in Wastewater	
Low pH	< 6.5
Ideal	7
High pH	>7.2

High pH (basic conditions) can be caused by certain laundry detergents, cleaning agents, chemicals, and high alkalinity source water. Photo developing labs and laundromats are common sources of wastewater that cause high pH. As the pH rises, the microbial population changes to organisms less efficient in the breakdown of wastewater.

Low pH (acidic conditions) can be influenced by cooking habits, low alkalinity in the water supply or acid-based cleaners. If there is an above normal use of dairy products, coffee, excessive baking, or home canning, lower pH levels in the wastewater stream are likely. Just like high pH levels, low pH levels will only allow certain microbes to survive, adversely influencing wastewater treatment. The microbes at low or high pH are not as efficient as the microbes that can survive at an average pH level.

The pH level can be easily identified by the odor of the system. Low pH has a very acidic smell that absorbs readily into clothing and is hard to remove. High pH often smells like the chemical or cleaner that was used at the wastewater source that is causing the high pH. Over a relatively short period of time, our olfactory sensors become accustomed to an odor. As a result, the odor test can only be used at the very start of a testing or inspection before our senses get used to the odor.

Temperature

Septic tank effluent on average is approximately 20 degrees (°F) warmer than the ambient ground temperature. Microbial activity doubles in population every time the temperature increases by 18°F (10°C) until the optimum temperature is reached. As the microbial activity doubles, the biodegradation of constituents increases. This means that oxygen uptake is more rapid at warmer temperatures, requiring air to be supplied at a higher rate. The waste degrades more quickly at warmer temperatures, so it need not be held in the treatment system as long when it is warm. The converse is also true: in the winter, oxygen uptake is low and air need not be supplied as fast. However, the waste takes longer to degrade, and would thus need to stay in the treatment system longer during cold months. The practical implication of this is that aerators are designed using summer temperatures and detention tanks are designed using winter temperatures.

If the temperature is too high, it will damage or kill the microbes that are providing treatment. The opposite effect occurs: as temperature decreases, so does microbial activity. It has been found that microbes used in wastewater treatment become dormant at 39.2°F (4°C). The ideal range for aerobic microbes decomposing the waste is between 77° and 95°F (Table 5.13). Just as the microbial population varies under certain pH and DO ranges, there are specific microbes that can thrive at particular temperature ranges (Table 5.14).

TABLE 5.13 Ideal temperature range in wastewater

Ideal Range in Wastewater	
Low temperature	77 °F
High temperature	95 °F

TABLE 5.14 Temperature classification of bacteria (M&E, 2003)

Type	Temperature range °C (F)	Optimum range °C (F)
Psychrophilic	10-30 (50-86)	12-18 (53.6-64.4)
Mesophilic	20-50 (68-122)	25-40 (77-104)
Thermophilic	35-75 (95-167)	55-65 (131-149)

Low temperature levels can be caused by cold water entering a leaky tank or leaky plumbing, the climate, or by laundry that is washed in cold water. If the temperature is too low, the biological activity in the system will slow or stop altogether.

High temperatures in a system can be caused by long hot showers, excessive laundering using hot water, dishwashers, or leaky hot water faucets. Temperatures that are over 100 °F can dissolve greases and oils held within a tank. In ideal temperatures, FOG would float to the top of the tank and separate from the wastewater stream. With high temperatures, eventually these dissolved greases and oils will end up in downstream components and clog them. Temperatures in excess of 122 °F can cause aerobic digestion and nitrification processes to cease. These higher temperatures in the treatment unit are unlikely for domestic wastes but may be possible in commercial units that use a lot of hot water such as commercial kitchens.

Alkalinity

Alkalinity refers to a wastewater's ability, or inability, to neutralize acids. The alkalinity in wastewater helps to buffer changes in pH caused by the addition of acids and is essential for the nitrification process (see page 47). Alkalinity typically occurs naturally in the source water.

Pathogens

The most critical component, in terms of what must be removed from wastewater, is pathogens. Pathogens are organisms that cause disease; they include viruses, protozoa, parasites, and bacteria. Examples in wastewater include Salmonella, Vibrio cholera, Entamoeba histolytica, and Cryptosporidium although almost all disease organisms could be present in wastewater. Viruses are organisms too small to be seen by light microscopy. They are an obligate parasite dependent on a host cell for its metabolic and reproductive needs. Pathogens may be found in wastewater generated anywhere in the house. Any human contact with water results in the potential to add pathogens to the environment. Because of their role in spreading disease, pathogens in wastewater make wastewater treatment a public health issue.

Fecal Coliform (FC)

Some of the microorganisms found in wastewater can cause disease while others are harmless. It is nearly impossible to identify all the pathogenic organisms in wastewater. Fecal coliform bacteria is an indicator bacteria common to the digestive systems of warm-blooded animals that is cultured in standard tests to indicate either contamination from sewage or the level of disinfection generally measured as number of colonies/100 mL or Most Probable Number (MPN). It is the most common test for pathogens because it is a relatively easy and inexpensive test. **MN Rules Chapter 7080.1100, Subp. 30, defines fecal coliform as the bacteria common to the digestive systems of humans that are cultured in standard tests. Counts of these organisms are typically used to indicate potential contamination from sewage or to describe a level of disinfection, generally expressed in colonies per 100 mL.** A colony-forming unit (cfu) is the term used to report the estimated number of bacteria in a water sample. Fecal coliform bacteria are fairly easy to test for, and their presence is an indication that wastewater and pathogens, which are more difficult to isolate and identify, may also be present. An average MPN for fecal coliform bacteria in septic tank effluent is 1,000,000 cells per 100 milliliters.

Sometimes total coliform bacteria is measured instead of fecal. Total coliform is a broader group of bacteria that constitute most of the intestinal flora of warm blooded animals (including the genera *Klebsiella* sp., *Enterobacter* sp., *Citrobacter* sp., or *Escherichia* sp.)

The removal of these organisms through the soil treatment process is the key design factor for systems, although E-coli is becoming the indicator organism when measuring in the environment. The requirement of soil separation found in MN Rules Chapter 7080 uses the removal of fecal coliform organisms, since their source is identified as the people using the system.

Vertical separation as the vertical measurement of unsaturated soil or sand between the bottom of the distribution medium and the periodically saturated soil level or bedrock (7080.1100, Subp 91). For a SSTS to properly treat wastewater, this zone of unsaturated soil must be present in order for beneficial bacteria and microbes in the soil to remove harmful bacteria and viruses from the wastewater. The periodically saturated soil level is commonly identified by the presence of redoximorphic features. For SSTS constructed after March 31, 1996, or in a Shoreland area/Wellhead protection area/serving food, beverage, or lodging establishments (SWF area), at least three feet of vertical separation distance is required. The LGU may allow up to a 15 percent reduction in this distance; this reduction must be specified in the local ordinance.

This amount of separation is allowed to be decreased according to Table 5.15 because the effluent is treated to either level A or B before reaching the soil.

Treatment products are registered in Minnesota as products that either: 1) treat residential strength sewage or 2) treat commercial or high-strength sewage as follows:

- Category A – treatment products for residential strength sewage
- Category B – treatment products for commercial or high-strength sewage

TABLE 5.15 Treatment Component Performance Levels and Method of Distribution by Texture Group¹

Vertical Separation (inches)	Texture Group ²		
	All sands and loamy sands	Sandy loam, loam, silt loam	Clay, clay loams
12 to 17 ³	Treatment level A Uniform distribution Timed dosing	Treatment level A Uniform distribution Timed dosing	Treatment level A Uniform distribution Timed dosing
18 to 35 ³	Treatment level B Uniform distribution Timed dosing	Treatment level B Uniform distribution Timed dosing	Treatment level B Uniform distribution
36+ ³	Treatment level A-2 or B-2 Uniform distribution Treatment level C	Treatment level A-2 or B-2 Uniform distribution Treatment level C	Treatment level A-2 or B-2 Uniform distribution Treatment level C

¹ The treatment component performance levels correspond with those established for treatment components under the product testing requirements in Table III in part 7083.4030.
² With less than 50 percent rock fragments.
³ Additional vertical separation distance is required as determined in part 7080.2150, subpart 3, item C, subitem (1), unit (b).

Category A Products and Treatment Levels

Within Category A, proprietary treatment products are listed by their ability to treat residential sewage to a specific treatment level. There are seven ‘Treatment Levels’ at which treatment products can be registered (Table 5.16). Products that meet the requirements of *Treatment Level A* meet the highest treatment standard in removing organic matter (15 mg/L CBOD₅), total suspended solids (15 mg/L TSS), and pathogenic indicator organisms (1,000 cfu/100 mL fecal coliform bacteria).

Products that meet *Treatment Level B* standards have been tested to reduce organic matter to 25 mg/L CBOD₅, total suspended solids to 30 mg/L TSS, and fecal coliform bacteria to 10,000 cfu/100 mL. Higher quality effluents produced using products that meet Treatment Levels A and B can be dispersed into suitable soils with reduced vertical separation and increased loading rates, depending upon soil characteristics. Soil dispersal requirements using treatment products that meet Treatment Levels A and B are specified in Minnesota Rules Chapter 7080.2150, Table IX. For a residential treatment product (Category A) listed under Treatment Level A, the product would also meet treatment standards for Treatment Level B and Treatment Level C. Recognize that for this performance testing CBOD₅ not BOD₅ should be evaluated by the lab.

Category B Products and Treatment Levels

Within Category B, products can be registered for treating high strength or commercial wastewater (i.e. restaurants, grocery stores). These products have been tested to specifically reduce wastewater from high strength to typical residential strength wastewater. These products would be listed as *Treatment Level C* products, or products tested to reduce wastewater to ‘typical’ residential strength (125 mg/L CBOD₅, 80 mg/L TSS, and 20 mg/L oil and grease).

Nutrient Listing

Table 5.16 also identifies those products registered for use in Minnesota that have been shown to reduce nitrogen and/or phosphorus. In order to be listed for nitrogen and phosphorus removal, independent third party testing has been completed and shown to meet a total nitrogen of <20 mg/L and a total phosphorus of <5 mg/L.

TABLE 5.16 The Seven Treatment Levels for Proprietary Treatment Products

Level	Parameters				
	CBOD ₅ (mg/L) ^a	TSS (mg/L) ^b	O&G (mg/L) ^c	FC (#/100 mL) ^d	Nutrient (mg/L)
A	15	15	--	1,000	--
A-2	15	15	--	--	--
B	25	30	--	10,000	--
B-2	25	30	--	--	--
C	125*	60	25	--	--
TN	--	--	--	--	<20 or actual value
TP	--	--	--	--	<5 or actual value

* BOD₅ = 170 mg/L

a Carbonaceous biochemical oxygen demand or CBOD₅ means the measure of the quantity of oxygen used by microorganisms in the aerobic oxidation of organic matter and other compounds containing carbon amount of oxygen required by bacteria while stabilizing, digesting, or treating the organic matter under aerobic conditions over a five-day incubation period while in the presence of a chemical inhibitor to block nitrification. CBOD₅ is commonly expressed in milligrams per liter (mg/L) (7080.0020, Subp. 12).

b Total suspended solids or TSS means solids that are in suspension in water and that are removable by laboratory filtering (7083.0020, Subp. 21).

c O&G means oil and grease, a component of sewage typically originating from foodstuffs such as animal fats or vegetable oils or consisting of compounds of alcohol or glycerol with fatty acids such as soaps and lotions, typically expressed in mg/L (7080.0020, Subp. 14).

d Fecal coliform or FC means bacteria common to the digestive systems of warm-blooded animals humans that are cultured in standard tests. Counts of these organisms are typically used to indicate potential contamination from sewage or to describe a level of disinfection, generally expressed in colonies per 100 mL (7080.0020, Subp. 30).

Category A: Designed to treat sewage with strength typical of a residential source when septic tank effluent is anticipated to be equal to or less than treatment Level C.

Category B: Designed to treat high-strength sewage when septic tank effluent is anticipated to be greater than treatment level C, including restaurants, grocery stores, mini-marts, group homes, medical clinics, residences, etc.

Total nitrogen and phosphorus reduction in Categories A and B

Nutrients

Nutrients are elements or compounds essential as raw material for growth and development of an organism; nitrogen, phosphorus and potassium are primary nutrients. Two nutrients are of concern in wastewater treatment: phosphorus and nitrogen. These nutrients have different chemical characteristics: phosphorus tends to bind to soil particles, while nitrogen is more mobile in the soil.

MN Rule Treatment Requirements for Nutrients

In MN Rules Chapter 7080.2210, Subp. 4, for systems from 2,500 – 5,000 gpd if the system will impact the water quality of an aquifer, as defined in part 4725.0100, Subp. 21, it must employ best management practices for nitrogen reduction developed by the commissioner to mitigate water quality impacts to groundwater.

For MSTs with design flows from 5,000 – 10,000 gpd there are additional nitrogen removal requirements:

1. **if the discharge from an MSTs will impact water quality of an aquifer, as defined in part 4725.0100, subpart 21, the effluent from an MSTs, in combination with the effective recharge to the groundwater, must not exceed a concentration of total nitrogen greater than 10 mg/L at the property boundary or nearest receptor, whichever is closest; and**
2. **if the discharge from an MSTs will not impact water quality of an aquifer, as defined in part 4725.0100, subpart 21, best management practices developed by the commissioner to mitigate water quality impacts to groundwater must be employed; and not exceed a groundwater discharge**

With MSTs, Phosphorus must also be considered. **According to MN Rules 7081.0070, Subp 4 (E) discharge from the system can not exceed a groundwater discharge of phosphorus to a surface water that exceeds the phosphorus standard to the receiving water. During the Preliminary Evaluation the Designer must consider whether the ordinary high water level of public waters will be within 500 feet of the proposed soil treatment and dispersal area and if so, a preliminary assessment of phosphorus impacts to the surface water must be performed.**

SSTs may have additional nutrient compliance criteria when their design flow exceeds 2,500 gpd. **From MN Rules Chapter 7080.1550, Subp. 5 -the compliance criteria for systems with a flow of greater than 2,500 gallons per day - systems designed under part 7080.2150, subpart 4, item A or B, must demonstrate that the additional nutrient reduction component required under those items is in place and functioning.**

Portions of the following nitrogen section were taken directly from the following reference: Oakley, S. 2005. Onsite Nitrogen Removal Text. in (M.A. Gross and N.E. Deal, eds.) University Curriculum Development for Decentralized Wastewater Management. National Decentralized Water Resources Capacity Development Project. University of Arkansas, Fayetteville, AR.

Full text and Figures available Online at:
www.onsiteconsortium.org/files/nitrogen.htm

Nitrogen

Nitrogen is an essential nutrient for the growth of plants and microorganisms. Nitrogen (N) is an essential chemical element and nutrient for all life forms. N constitutes 78 percent of the atmosphere by volume and is present in surface water and groundwater as ammonia (NH_3), nitrite (NO_2^-), nitrate (NO_3^-), and organic nitrogen. Total nitrogen is the measure of the complete nitrogen content in wastewater including nitrate (NO_3^-), nitrite (NO_2^-), ammonia (NH_3), ammonium (NH_4^+), and organic nitrogen, expressed as mg/L of N; all these forms of nitrogen, as well as nitrogen gas (N_2), can be converted from one form to another biochemically and are components of the nitrogen cycle.

- NH_3 is the non-ionized form of reduced nitrogen.
- NH_4^+ is the ionized form of reduced nitrogen usable by plants.
- NO_3^- is the stable oxidized form of nitrogen usable by plants and usually not degraded in groundwater; nitrifying bacteria can convert nitrite (NO_2^-) to nitrate (NO_3^-) in the nitrogen cycle.
- TKN is total Kjeldahl nitrogen, which is the measure of the total concentration of organic nitrogen, ammonia, and ammonium nitrogen.

- NO_2^- is the unstable oxidized form of nitrogen.
- Organic N is the nitrogen bound in plant and animal matter, primarily amino acids and proteins; the amount of organic nitrogen can be obtained by separately measuring the ammonia nitrogen and subtracting that value from the total Kjeldahl nitrogen.

As nitrogen moves through the treatment system, it changes from ammonia to nitrate. While it is possible for nitrate to change into nitrogen gas in some systems, standard trench and bed systems do not facilitate this change, so the nitrate may move into groundwater. A range level of nitrogen in septic tank effluent is 25-124 milligrams per liter.

In drinking water, which is often from groundwater, high levels of nitrogen can be toxic to infants, causing methemoglobinemia, “blue baby syndrome.” Ammonia in surface waters can be toxic to fish.

Advanced pretreatment may be required to minimize the release of nitrogen to the environment.

The principal forms of nitrogen of concern in onsite wastewater treatment and soil-groundwater interactions are Organic-N, $\text{NH}_3/\text{NH}_4^+$, N_2 , NO_2^- , and NO_3^- (Rittman & McCarty, 2001; Sawyer et al., 1994; US EPA, 1993). Because these forms still represent four possible oxidation states that can change in the environment, it is customary to express the various forms of nitrogen in terms of nitrogen rather than the specific chemical compound: Organic-N, (35mg/L) NH_3 -N, NH_4^+ -N, N_2 -N, NO_2^- -N, and NO_3^- -N. Thus, for example, 10 mg/L of NO_3^- -N is equivalent to 45 mg/L of NO_3^- ion.

The Nitrogen Cycle in Soil-Groundwater Systems

Transformation of the principal nitrogen compounds (Organic-N, NH_3 -N, NH_4^+ -N, N_2 -N, NO_2^- -N, and NO_3^- -N) can occur through several key mechanisms in the environment: fixation, ammonification, synthesis, nitrification, and denitrification (US EPA, 1993).

1. Nitrogen Fixation

Nitrogen fixation is the conversion of nitrogen gas into nitrogen compounds that can be assimilated by plants. Biological fixation is the most common, but fixation can also occur by lightning and through industrial processes:

Biological: N_2 Organic-N
 Lightning: N_2 NO_3^-
 Industrial: N_2 NO_3^- ; $\text{NH}_3/\text{NH}_4^+$

2. Ammonification

Ammonification is the biochemical degradation of organic-N into NH_3 or NH_4^+ by heterotrophic bacteria under aerobic or anaerobic conditions.

Organic-N + Microorganisms → $\text{NH}_3/\text{NH}_4^+$


Some organic-N cannot be degraded and becomes part of the humus in soils.

3. Synthesis

Synthesis is the biochemical mechanism in which NH_4^+ -N or NO_3^- -N is converted into plant protein (Organic-N):





Nitrogen fixation is also a unique form of synthesis that can only be performed by nitrogen-fixing bacteria and algae (WEF, 1998):



4. Nitrification


Nitrification is the biological oxidation of NH_4^+ to NO_3^- through a two-step autotrophic process by the bacteria *Nitrosomonas* and *Nitrobacter* (Rittman and McCarty, 2001; Sawyer, et al., 1994):




The two-step reactions are usually very rapid and hence it is rare to find nitrite levels higher than 1.0 mg/L in water (Sawyer, *et al.*, 1994). The nitrate formed by nitrification is, in the nitrogen cycle, used by plants as a nitrogen source (synthesis) or reduced to N_2 gas through the process of denitrification. Nitrate can, however, contaminate groundwater if it is not used for synthesis or reduced through denitrification as shown in Figure 1.

5. Denitrification

NO_3^- can be reduced, under anoxic conditions, to N_2 gas through heterotrophic biological denitrification as shown in the following unbalanced equation (US EPA, 1993):




The above equation is identical to the equation for the biological oxidation of organic matter with the exception that NO_3^- is used as an electron acceptor instead of O_2 :



A large variety of heterotrophic bacteria can use nitrate in lieu of oxygen for the degradation of organic matter under anoxic conditions. If O_2 is present, however, the bacteria will preferentially select it instead of NO_3^- (US EPA, 1993). Thus it is very important that anoxic conditions exist in order that NO_3^- will be used as the electron acceptor. A carbon source is required as the electron donor in the above equation for denitrification to occur.

Autotrophic denitrification is also possible with either elemental sulfur or hydrogen gas used as the electron donor by autotrophic bacteria as shown in the following unbalanced equation (Rittman and McCarty, 2001):



Health Effects from Groundwater Contamination with Nitrates

Contamination of groundwater with nitrates is a problem in many parts of the U.S. and has been widely documented (Bouchard, et al., 1992). Potential health concerns where contaminated groundwater is used as a drinking water source include methemoglobinemia, carcinogenesis, and birth defects.

Methemoglobinemia

High nitrate levels in drinking water supplies can cause methemoglobinemia in infants, especially those less than six months old (Bouchard, et al., 1992). After ingestion, nitrate is reduced to nitrite in the gut of the infant. The absorbed nitrite reacts with hemoglobin in the blood, forming methemoglobin. Methemoglobin, unlike hemoglobin, cannot carry oxygen. As more of the blood hemoglobin is converted to methemoglobin, the oxygen-carrying capacity of the blood is significantly reduced. Oxygen starvation of the blood can result in a bluish discoloration of the body, which is called “blue-baby” syndrome or methemoglobinemia. To prevent methemoglobinemia, the maximum contaminant level of nitrate in drinking water has been set at 10 mg/L as NO_3^- -N by the US EPA (Bouchard, et al., 1992).

Carcinogenesis

High nitrate levels in drinking water could potentially have carcinogenic effects through the formation of nitrosamines. Nitrates in the human body can be converted to nitrites and then to nitrosamines, several forms of which have been classified as potential human carcinogens (Bouchard, et al., 1992). While several scientific studies have shown a positive correlation between some types of cancers and nitrate intake in animals, a cause-effect relationship for risk of cancer has not yet been demonstrated conclusively.

Birth Defects

Epidemiological studies in Canada and South Australia have shown a statistically significant increase in congenital malformations associated with nitrate-rich well water (Bouchard, et al., 1992). These studies, however, are considered to be too limited in scope to deduce a causal association between birth defects and nitrate ingestion. Experimental animal studies have not shown significant effects from elevated nitrate ingestion.

Surface Water Pollution with Nitrogen

When excess nitrogen concentrations are discharged to surface waters, several deleterious effects may occur, depending on the environmental conditions.

Eutrophication

Phosphorus is oftentimes the limiting nutrient for the growth of algae and aquatic plants in surface waters. Thus, any phosphorus can cause the stimulation of growth, resulting in algal blooms or overgrowth of aquatic plants, which can have serious consequences for the receiving water such as odors, accumulation of unsightly biomass, dissolved oxygen depletion due to biomass decay, and loss of fish and shellfish. In some cases, nitrogen is the limiting nutrient and excess nitrogen is the cause for excessive plant growth.

Oxygen Demand through Nitrification

The oxidation of Organic-N and NH_3 -N/ NH_4^+ -N to NO_3^- -N through the process of


nitrification can exert a significant oxygen demand on the receiving water, which is known as the nitrogenous biochemical oxygen demand (NBOD) (Metcalf and Eddy, 1991). The NBOD of a wastewater can even be greater than the carbonaceous biochemical oxygen demand (CBOD), although it may not be exerted as rapidly. The rate of nitrification is dependent on several environmental factors, which include the population of nitrifying bacteria, temperature, alkalinity, and availability of dissolved oxygen.

Ammonia Toxicity to Aquatic Organisms

Nitrogen in the form of $\text{NH}_3\text{-N}$ can cause acute toxicity to several species of fish. Because the concentration of $\text{NH}_3\text{-N}$ as opposed to $\text{NH}_4^+\text{-N}$ is pH dependent, criteria for ambient water quality have been set for unionized ammonia as a function of pH and temperature (Sawyer, et al., 1994). Many municipal wastewater treatment plants in the US are required to nitrify their effluent in order to avoid ammonia toxicity in receiving waters.

Biological Nitrification

As mentioned above, nitrification is a two-step autotrophic process (nitrifiers use CO_2 instead of organic carbon as their carbon source for cell synthesis) for the conversion of NH_4^+ to $\text{NO}_3^-\text{-N}$. During this energy yielding reaction some of the NH_4^+ is synthesized into cell tissue giving the following overall oxidation and synthesis reaction (US EPA, 1993):



The above equation poses several key design constraints on nitrification systems. For each mole of NH_4^+ oxidized, 1.89 moles of oxygen are required and 1.98 moles of hydrogen ions will be produced. Or, in mass terms, 4.32 mg of O_2 are required for each mg of $\text{NH}_4^+\text{-N}$ oxidized, with the subsequent loss of 7.1 mg of alkalinity as CaCO_3 in the wastewater, and the synthesis of 0.1 mg of new bacterial cells. Stated yet another way, the oxidation of, for example, 20 mg/L of $\text{NH}_4^+\text{-N}$ would require the consumption of 86.4 mg/L of dissolved oxygen, the destruction of 141.4 mg/L of alkalinity as CaCO_3 , and the production of 2.6 mg/L of nitrifying organisms (US EPA, 1993).

Nitrification can thus exert a very high nitrogenous biochemical oxygen demand (NBOD) in addition to the carbonaceous BOD (CBOD) as shown in Figure 3-3. MN Rules Chapter 7080.1100, Subp. 12 defines CBOD_5 as the measure of the amount of oxygen required by bacteria while stabilizing, digesting, or treating the organic matter under aerobic conditions over a five-day incubation period while in the presence of a chemical inhibitor to block nitrification. CBOD_5 is commonly expressed in milligrams per liter (mg/L).

Using the above equation, a septic tank effluent of 40 mg/L $\text{NH}_4^+\text{-N}$ would have a NBOD of about 184 mg/L in addition to the CBOD. This factor must be included in the design of nitrification systems to be sure there is sufficient dissolved oxygen (DO) within the system for nitrification to occur. To process 40 mg/L of NH_4^+ , you must add 184 mg/L of DO. Nitrification can also cause a significant drop in pH if there is not adequate buffering capacity (alkalinity) in the wastewater.

Process Microbiology

Nitrifying organisms exhibit growth rates that are much lower than those for heterotrophic bacteria. As a result, the rate of nitrification is controlled first by concurrent

heterotrophic oxidation of CBOD; as long as there is high organic (CBOD) loading to the system, the heterotrophic bacteria will dominate. Nitrification systems must thus be designed to allow sufficient detention time within the system for nitrifying bacteria to grow. Heterotrophic organisms can also play a key role in limiting oxygen transfer to nitrifying bacteria, especially in attached-growth systems (Rittman and McCarty, 2001; US EPA, 1993). After competition with heterotrophs, the rate of nitrification will be limited by the concentration of available $\text{NH}_4^+\text{-N}$ in the system. Temperature, pH, and chemical inhibitors can also play a key role as discussed below.

At low BOD_5/TKN ratios (0.5 to 3) the population of nitrifying bacteria is high and nitrification should not be influenced by heterotrophic oxidation of CBOD (Metcalf & Eddy, 1991); this type of nitrification process is termed separate-stage nitrification. At higher BOD_5/TKN ratios, the fraction of nitrifying organisms in the system is much lower due to heterotrophic competition from oxidation of CBOD; this process is termed single-stage nitrification.

Separate-stage nitrification is highly desirable from the standpoint of process control and operation. Many onsite systems presently used or proposed for nitrogen removal, however, because of the interest in reducing size and system footprint, employ single-stage nitrification; examples include aerobic treatment units with short hydraulic detention times and sand filters or media filters that are heavily loaded organically. Single-stage systems may require more rigorous process control to ensure adequate nitrification rates.

Dissolved Oxygen Requirements and Organic Loading Rates

Suspended Growth Systems

The concentration of DO has a significant effect on nitrification in wastewater treatment. Although much research has been performed, practical experience has shown that DO levels must be maintained at approximately 2.0 mg/L in suspended-growth (aerobic) systems, especially when $\text{NH}_4^+\text{-N}$ loadings are expected to fluctuate widely (US EPA, 1993); this may or may not be the case in domestic onsite wastewater systems.

Attached-Growth Systems

For attached-growth systems, which include both submerged and nonsubmerged processes (Crites and Tchobanoglous, 1998), DO levels must be maintained at levels that are at least 2.7 times greater than the $\text{NH}_4^+\text{-N}$ concentrations in order to prevent oxygen transfer through the biofilm from limiting nitrification rates (US EPA, 1993). This is usually overcome in practice by using lower organic surface loadings than what would be normally applied for CBOD removal to allow for growth of nitrifying organisms; otherwise the heterotrophic organisms will dominate the bacterial film within the attached-growth media. For trickling filters, for example, the organic loading rate for nitrification is only about 1/5 to 1/8 of the CBOD loading for CBOD removal (Metcalf & Eddy, 1991; US EPA, 1993). Recirculation of effluent through the attached growth media, and use of special media, such as trickling filter plastic media with high specific surface areas, is also used to lower organic surface loadings and to promote high oxygen transfer rates.

Table 5.17 shows design organic loading rates for various attached-growth systems to achieve nitrification. Unfortunately, organic loading rates for onsite attached-growth systems are not well defined even for CBOD removal, let alone nitrification (Crites and

Tchobanoglous, 1998). The more commonly used hydraulic loading rates as cited in the literature show mixed results for nitrification. This is no doubt due, at least in part, to varying organic loading rates that were not taken into consideration since the CBOD_5 of septic tank effluent can vary greatly, ranging from less than 100 to 480 mg/L (Ayres Associates, 1993).

TABLE 5.17 Design Loading Rates for Attached Growth Systems to Achieve >85% Nitrification

Process	Hydraulic Loading Rate, gpd/ft ²	Organic Loading Rate, lbs. BOD/ft ² -day	State of Knowledge for Design
Trickling Filters ¹			
Rock Media	30-900	0.04-0.12 (0.04-0.64)	Well Known
Plastic Media	288-1700	0.10-0.25 (0.50-2.00)	Well Known
Sand Filters			
Single-Pass	0.4-1.2	0.000135-0.002	Lesser Known ²
Recirculating	3-5	0.002-0.008	Lesser Known ²
Textile Filters			
Single-Pass	10	0.01	Lesser Known ²
Multi-Pass ³ (Partial Nitrification)	30	0.03	Lesser Known ²

¹ The values for trickling filters given for both hydraulic and organic loadings are the ranges for low rate and high rate filters. Rock filters were assumed to have a depth of 8 ft. and plastic filters a depth of 10 ft. The numbers in parentheses for organic loadings are the values for CBOD removal only without nitrification.

² These systems have not traditionally been designed using organic loading rates to achieve nitrification. High strength wastes thus could affect nitrification performance.

³ At this organic loading rate only 59-76% nitrification was achieved (Leverenz, et al., 2001).

Adapted from Converse (1999); Crites and Tchobanoglous (1998); Leverenz, et al. (2001); Metcalf & Eddy (1991); and US EPA (1993).

pH and Alkalinity Effects on Nitrification

The optimum pH range for nitrification is 6.5 to 8.0 (US EPA, 1993). Because nitrification consumes about 7.1 mg of alkalinity (as CaCO_3) for every mg of $\text{NH}_4^+\text{-N}$ oxidized, in low alkalinity wastewaters there is a risk that nitrification will lower the pH to inhibitory levels. If, for example, it were desired to nitrify 40 mg/L of $\text{NH}_4^+\text{-N}$, approximately 284 mg/L of CaCO_3 would be required to maintain pH levels; this may be beyond the capabilities of some wastewaters derived from water sources that do not contain relatively high alkalinity.

Temperature Effects

Temperature has a significant effect on nitrification that must be taken into consideration for design (US EPA, 1993). In general, colder temperatures require longer cell residence times in suspended-growth systems and lower hydraulic loading rates in attached-growth systems due to slower growth rates of nitrifying bacteria.

Effect of Inhibitors

Nitrifying bacteria are much more sensitive than heterotrophic bacteria and are susceptible to a wide range of organic and inorganic inhibitors as shown in Table 5.18. As has occurred in centralized wastewater treatment (US EPA, 1993), there is a need to establish a methodology for onsite wastewater systems for assessing the potential for, and occurrence of, nitrification inhibition. The introduction of chemicals shown in Table 5.18 (next page) can destroy the nitrifying bacterial populations. If these systems are not continuously monitored, the effects of these chemicals will go unnoticed.

5-54 ■ SECTION 5: Wastewater Sources and Flows

TABLE 5.18 Examples of Nitrification Inhibitors

Inorganic Compounds		Organic Compounds
Zinc	Sodium azide	Acetone
Free Cyanide	Hydrazine	Carbon Disulfide
Perchlorate	Sodium cyanate	Chloroform
Copper	Potassium chromate	Ethanol
Mercury	Cadmium	Phenol
Chromium	Arsenic	Ethylenediamine
Nickel	Fluoride	Hexamethylene diamine
Silver	Lead	Aniline
Cobalt	Free ammonia	Monoethanolamine
Thiocyanate	Free nitrous acid	
Sodium cyanide		


Since heterotrophic bacteria are much more resilient than nitrifying bacteria, and because many of the inhibitory compounds are biodegradable organics, inhibitory effects can oftentimes be controlled by designing separate-stage nitrification systems (US EPA, 1993). In separate-stage systems the CBOD is first removed along with any biodegradable inhibitory compounds; the nitrifying organisms, which are in effect protected in the second stage, are then used to nitrify the low-CBOD, high-NH₄⁺-N effluent (Figure 5).

Example: Calculation of alkalinity and oxygen requirements for nitrification

Determine the alkalinity requirements for complete nitrification for a septic tank effluent that has a CBOD of 150 mg/L and an Organic-N and NH₄⁺-N concentration of 40 mg/L. What would the NBOD of this wastewater be?

Solution

- Write a balanced equation for the nitrification reaction and include mass relationships.



GMW = gram molecular weight

Milliequivalent mass of CaCO₃ = 50 mg/meq

0.14 meq as H⁺ in terms of equivalent CaCO₃ = 0.14 meq (50 mg CaCO₃/meq) = 7.1 mg as CaCO₃ mg as CaCO₃

- Determine alkalinity requirements.

Alkalinity required = 40 mg/L Total-N (7.1 mg/L CaCO₃/mg N) = 284 mg/L as CaCO₃

- Determine the NBOD.

NBOD = 40 mg/L total-N (4.32 mg O₂/mg N) = 173 mg/L

Comment: The alkalinity requirements here exceed the 200 mg/L as CaCO₃ that has been reported to be a typical alkalinity concentration in strong, untreated domestic wastewater (Metcalf & Eddy, 1991). Alkalinity does increase as a result of water use, and the incremental range for septic tank effluent has been reported from 60-120 mg/L as CaCO₃ (Crites and Tchobanoglous, 1998). In areas with low-alkalinity source waters, however, nitrification could be limited. Note that the NBOD exceeds the CBOD of the septic tank effluent, which underscores the oxygen requirements for nitrification.

Summary of Nitrification Processes

Table 5.19 summarizes the various onsite technologies and their advantages and disadvantages for effective nitrification based on the factors discussed above. The available information suggests that an effective design strategy for nitrification in onsite systems would be to use attached-growth processes with relatively low organic loadings (compared to CBOD removal only) and deep, well-aerated media (such as a 2 ft. deep SPSF). This type of system would approach a separate-stage nitrification with its advantages while maintaining the cost and simplicity of a single-stage system. In this design the heterotrophic bacteria would grow in the upper levels and remove CBOD and inhibitory compounds; nitrifying bacteria would grow in the lower levels and would be protected both from shock loadings and temperature extremes. A single pass sand filter, which is well known for its nitrification reliability, is an example of this design.

TABLE 5.19 Onsite Technologies for > 85% Nitrification

Process	Effectiveness	Onsite status
Suspended growth: aerobic units	Insufficient design and performance data	Operation and maintenance unknown
Attached Growth: Single-Pass Sand Filters (SPSF)	Need more design data for organic loadings for nitrification	Fair to good performance in cold climates
Recirculating Sand Filters (RSF)	Need more design data for organic loadings for nitrification	Poorer performance in cold climates than SPSFs
Single-Pass Textile Filters	Limited data to date. Probably similar to SPSF	Need design data for organic loadings for nitrification
Multi-Pass Textile Filters	Limited data to date. Probably similar to RSF	Need design data for organic loadings for nitrification and performance in cold climates

Biological Denitrification

Denitrification is a biological process that uses NO_3^- as the electron acceptor (hence nitrification must precede denitrification) instead of O_2 to oxidize organic matter (heterotrophic denitrification) or inorganic matter such as sulfur or hydrogen (autotrophic denitrification) under anoxic conditions (Rittmann and McCarty, 2001). In the process NO_3^- is reduced to N_2 gas. Because the principal biochemical pathway is a modification of aerobic pathways (i.e., NO_3^- is used as the electron acceptor instead of O_2), the denitrification process is said to occur under anoxic conditions as opposed to anaerobic conditions (where obligate anaerobic organisms would be present). Denitrifying bacteria, whether heterotrophic or autotrophic, are facultative aerobes and can shift between oxygen respiration and nitrate respiration. For heterotrophic denitrification, the carbon source can come from the original wastewater, bacterial cell material, or an external source such as methanol or acetate. For autotrophic denitrification, which is common in water treatment but not wastewater treatment, the electron donor can come from elemental sulfur or hydrogen gas (Rittmann and McCarty, 2001).

Heterotrophic Denitrification

Wastewater as Carbon Source

The following unbalanced equation illustrates the process when wastewater or bacterial cell material is used as the carbon source (US EPA, 1993):

5-56 ■ SECTION 5: Wastewater Sources and Flows

Heterotrophic



As is shown in the following example, the reduction of 1 mg of NO_3^- is equivalent to 2.86 mg of O_2 . Thus, for example, a wastewater with an ultimate BOD (BOD_L) of 200 mg/L could potentially reduce almost 70 mg/L of NO_3^- -N if the wastewater were used as the carbon source (US EPA, 1993). This does not happen in practice, however, because a portion of the organic carbon in the wastewater must be used for cell synthesis and not nitrate reduction.


Example: Calculation of stoichiometric equations for nitrate

REDUCTION USING THE WASTEWATER AS THE CARBON SOURCE. Determine the theoretical amount of NO_3^- -N that could be removed if septic tank effluent, which has a BOD₅ of 120 mg/L, is used as the carbon source. What quantity could be removed if the raw wastewater influent to the septic tank, with a BOD₅ of 220 mg/L, were used as the carbon source?

Solution

1. Write the half-reactions for oxygen and nitrate as electron acceptors (Rittmann and McCarty, 2001).

Oxygen:




32 GMW

8 g [0.25(32) = 8]

8 mg

Nitrate:



62 GMW

14 GMW as N

2.8 g [0.2(14) = 2.8]

2.8 mg

2. Determine the stoichiometric equivalency of oxygen and nitrate.

For the acceptance of one electron, the above equations show that 8 mg of O_2 is equivalent to 2.8 mg of NO_3^- -N, or that 1.0 mg of NO_3^- -N is equivalent to 2.86 mg of O_2 .

$$\frac{8 \text{ mg O}_2/\text{e}^- \text{ equiv.}}{2.8 \text{ mg NO}_3^- \text{-N}/\text{e}^- \text{ equiv.}} = 2.86 \text{ mg O}_2/\text{mg NO}_3^- \text{-N}$$

3. Determine the BOD_L of the wastewater.

The stoichiometric equations must be based on the ultimate BOD (BOD_L) rather than the more commonly used BOD₅. The BOD₅ of wastewater can range between 68% to 94% of the BOD_L, depending on the value of the BOD reaction rate constant, *k* (Sawyer, et al., 1994). It will be assumed here that *k* (base *e*) is 0.23 d⁻¹ at 20 °C, a typical value for domestic wastewater (Metcalf & Eddy, 1991).

Septic Tank Effluent:

$$\text{BOD}_L = \frac{\text{BOD}_5}{(1 - e^{-kt})} = \frac{120}{(1 - e^{-0.23(5)})} = \frac{120}{0.68} = 176 \text{ mg/L}$$

Septic Tank Influent:

$$\text{BOD}_L = \frac{\text{BOD}_5}{(1 - e^{-kt})} = \frac{220}{(1 - e^{-0.23(5)})} = \frac{220}{0.68} = 323 \text{ mg/L}$$

4. Determine the quantity of NO_3^- -N that could theoretically be reduced.

Septic Tank Effluent:

$$\text{NO}_3^- \text{-N Reduction} = \frac{176 \text{ mg O}_2 \text{ demand/L}}{2.86 \text{ mg O}_2 / \text{mg NO}_3^- \text{-N}} = 61.5 \text{ mg/L}$$

Septic Tank Influent:

$$\text{NO}_3^- \text{-N Reduction} = \frac{323 \text{ mg O}_2 \text{ demand/L}}{2.86 \text{ mg O}_2 / \text{mg NO}_3^- \text{-N}} = 113 \text{ mg/L}$$

Comment: In practice the equivalency of 2.86 mg O_2 /mg NO_3^- -N is not achievable because a portion of the electron donor (i.e., the wastewater) must be used to provide carbon for cell synthesis; thus more electron donor will be needed to reduce a given amount of NO_3^- -N than is predicted by the half-reactions alone. For complex organic matter such as wastewater, the stoichiometric equivalency can range from 3.46-5.07 mg BOD_L /mg NO_3^- -N, with 4.0 mg BOD_L /mg NO_3^- -N used as a rule of thumb (Rittmann and McCarty, 2001). In terms of BOD_5 , this amounts to 2.72 mg BOD_5 /mg NO_3^- -N for k (base e) = 0.23 d^{-1} .

Example: Recalculation of stoichiometric equations for nitrate reduction using the wastewater as the carbon source

Recalculate the amount of NO_3^- -N that could be removed in Example 5 using the “rule of thumb” stoichiometric equivalency.

Solution

1. Express the stoichiometric equivalency in terms of the commonly used BOD_5 .

$$\text{BOD}_5 = 0.68\text{BOD}_L \text{ for } k = 0.23 \text{ d}^{-1} \text{ (base e)}$$

$$\frac{4.0 \text{ mg BOD}_L}{\text{mg NO}_3^- \text{-N}} = 0.68(4.0) = \frac{2.72 \text{ mg BOD}_5}{\text{mg NO}_3^- \text{-N}}$$

2. Determine the quantity of NO_3^- -N that could theoretically be reduced.

Septic Tank Effluent:

$$\text{NO}_3^- \text{-N Reduction} = \frac{120 \text{ mg BOD}_5/\text{L}}{2.72 \text{ mg BOD}_5 / \text{mg NO}_3^- \text{-N}} = 44 \text{ mg/L}$$

5-58 ■ SECTION 5: Wastewater Sources and Flows

Septic Tank Influent:


$$\text{NO}_3^- \text{-N Reduction} = \frac{220 \text{ mg BOD}_5/\text{L}}{2.72 \text{ mg BOD}_5/\text{mg NO}_3^- \text{-N}} = 81 \text{ mg/L}$$

Comment: To achieve the maximum nitrate reduction potential, the wastewater should be used at the point of highest CBOD. This may not occur if septic tank effluent, for example, or a recirculation tank from a packed bed filter system, is used as the point of application of the carbon source. Imperfect mixing of the wastewater carbon source with the nitrified effluent, and the absence of anoxic conditions, can also cause a reduction in denitrification.


External Carbon Source

In cases where there is insufficient CBOD left in the wastewater to serve as an electron donor for denitrification, an external carbon source must be supplied. Although there are many possibilities, methanol and acetate have been studied the most and their stoichiometry is shown below (Rittmann and McCarty, 2001; US EPA, 1993):

Methanol:



Acetate:



There are few examples in the literature of an external carbon source being used for onsite denitrification. Although methanol has been studied extensively in centralized wastewater treatment plants, it is probably not a good choice for onsite systems because of its toxicity and potential for contaminating groundwater supplies. Gold, et al., (1989) reported on the use of both methanol and ethanol as an external carbon source in a recirculating sand filter system with an anoxic rock filter for denitrification. They noted that although the total nitrogen removal rate was as high as 80%, the use of the chemicals required operation and maintenance of the carbon source supply system, including an on-site storage facility, a metering pump mechanism, and supplying a diluted carbon source solution. They concluded that the external carbon source could probably best be handled by a wastewater management district or a private O & M contractor (Gold, et al., 1989).

Example: Design of denitrification system using methanol as the carbon source


Determine the methanol requirements for an onsite denitrification system using a recirculating sand filter. The following conditions apply:

1. Household flowrate = 192 gpd
2. The concentration of $\text{NO}_3^- \text{-N}$ to be removed is 40 mg/L
3. Characteristics of Methanol:
 - 99.90% Solution = 0.7913 g $\text{CH}_3\text{OH}/\text{ml}$
 - 10.00% Solution = 0.08 g $\text{CH}_3\text{OH}/\text{ml}$

SECTION 5: Wastewater Sources and Flows ■ 5-59

Solution

- Write the balanced equation for denitrification and include mass relationships.



- Determine the required concentration of methanol.

$$\text{Required concentration of CH}_3\text{OH} = \frac{2.47 \text{ mg}}{\text{mg NO}_3^- \text{-N}} (40 \text{ mg/L NO}_3^- \text{-N}) = 98.8 \text{ mg/L} \approx 100 \text{ mg/L}$$


- Determine the methanol requirement.

$$\text{CH}_3\text{OH requirement} = (100 \text{ mg/L})(150 \text{ gpd})(3.78 \text{ L/gal})(1 \text{ g}/1000 \text{ mg}) = 56.7 \text{ g/day}$$

10% Solution:

$$\frac{56.7 \text{ g/day}}{\text{mos.}} = 709 \text{ mL/day} = 21.3 \text{ L/month} = 5.6 \text{ gallons/month} \approx \text{one 55 gallon drum}/10$$

- Determine the BOD_L of methanol.



32 GMW	32 GMW			
32 mg	48 mg			
1 mg	1.5 mg			

- Determine the ratio of BOD_L/NO₃⁻-N reduced.

$$\frac{150 \text{ mg/L BOD}_L}{40 \text{ mg/L NO}_3^- \text{-N}} = 3.75 \text{ mg BOD}_L/\text{mg NO}_3^- \text{-N reduced.}$$

Comment. This example shows that the required BOD_L of methanol is higher than that predicted by half-reactions alone (2.86 mg BOD_L/mg NO₃⁻-N) because a portion of the methanol was used for cell synthesis as can be seen in the balanced equation. Note that 3.57 mg of alkalinity as CaCO₃ was produced per mg of NO₃⁻-N reduced. Thus approximately half of the alkalinity lost during nitrification can be recovered through denitrification with methanol or wastewater as the carbon source.

Example: Design of denitrification system using acetic acid as the carbon source

Determine the acetic acid requirements for an onsite denitrification system using a recirculating sand filter. Assume the acetic acid could be used in the form of vinegar (5% solution). The following conditions from Example 6 apply:

- Household flow rate = 192 gpd
- The concentration of NO₃⁻-N to be removed is 40 mg/L

5-60 ■ SECTION 5: Wastewater Sources and Flows


3. Characteristics of acetic acid:

99.5% Solution = 1.05 g CH₃COOH/mL

5.0% Solution = 0.05 g CH₃COOH/mL

Solution

1. Write the balanced equation for denitrification and include mass relationships (Rittmann and McCarty, 2001).



2. Determine the required concentration of acetic acid.

$$\text{Required concentration of CH}_3\text{COOH} = \frac{3.73 \text{ mg}}{\text{mg NO}_3^- \text{-N}} (40 \text{ mg/L NO}_3^- \text{-N}) = 149 \text{ mg/L}$$

3. Determine the acetic acid requirement.

$$\text{CH}_3\text{COOH requirement} = (149 \text{ mg/L})(150 \text{ gpd})(3.78 \text{ L/gal})(1 \text{ g}/1000 \text{ mg}) = 84.5 \text{ g/day}$$

5% Solution:

$$\frac{84.5 \text{ g/day}}{0.05 \text{ g/mL}} = 1690 \text{ mL/day} = 50.7 \text{ L/month} = 13.4 \text{ gallons/month} \approx \text{one 55 gallon drum}/4 \text{ mos.}$$

0.05 g/mL

4. Determine the BOD_L of acetic acid.



60 GMW	32 GMW
60 mg	64 mg
1 mg	1.07 mg

$$\begin{aligned} 1 \text{ mg of CH}_3\text{COOH} &= 1.07 \text{ mg BOD}_L \\ 149 \text{ mg/L CH}_3\text{COOH} &= 159 \text{ mg/L BOD}_L \end{aligned}$$

5. Determine the ratio of BOD_L/NO₃⁻-N reduced.

$$\frac{159 \text{ mg/L BOD}_L}{40 \text{ mg/L NO}_3^- \text{-N}} = 3.97 \text{ mg BOD}_L/\text{mg NO}_3^- \text{-N reduced.}$$

Comment: In this example, unlike methanol or wastewater, acetic acid adds acid to the system, which is neutralized by the production of alkalinity through denitrification (0.87 meq of H⁺ from acetic acid would be neutralized by the 0.87 meq of HCO₃⁻ produced by denitrification). Thus there would not be a 50% recovery of the alkalinity lost through nitrification if acetic acid were used as the carbon source (Rittmann and McCarty, 2001).

Phosphorus

In temperate regions, such as Minnesota, phosphorus (P) is the nutrient primarily responsible for accelerating eutrophication of freshwaters, because phosphorus is usually in limited supply relative to plant demand. Wastewater contains phosphorus from feces and detergents. Phosphorus in wastewater can be categorized as orthophosphate, condensed phosphates, or organic phosphorus (Crites and Tchobanoglous 1998):

1. Orthophosphate (o-phosphate) includes H_3PO_4 , H_2PO_4^- , HPO_4^{2-} , and PO_4^{3-} . In waters with a pH close to 7, H_2PO_4^- and HPO_4^{2-} are the predominant orthophosphate forms.
2. Condensed phosphates include various polyphosphate forms such as pyrophosphate ($\text{P}_2\text{O}_7^{4-}$) and $\text{P}_3\text{O}_{10}^{5-}$. Derived primarily from laundry detergents and other cleansers, condensed phosphates convert slowly to orthophosphate.
3. Organic phosphorus includes phosphorus incorporated with organic compounds, such as sugars, phospholipids, and nucleotides.

Approximately 50% of phosphorus in raw wastewater is orthophosphate, 40% polyphosphates, and 10% organic phosphorus. Estimated phosphorus loads from household sources average 1.0 to 1.3 kg/capita/year (Jenkins and Hermanowicz, 1991), broken down as follows:

- Human waste: 0.6 kg/capita/year
- Laundry detergents (with no phosphorus limitation): 0.3 kg/capita/year
- Other household detergents and cleaners: 0.1 kg/capita/year

Total phosphorus (TP) is the sum of all forms of phosphorus in effluent. Each of these forms is expressed in terms of milligrams per liter (mg/L). A typical value for phosphorus in septic tank effluent is seven - ten mg/L.

A small amount (~10%) of phosphorus removal will occur in a septic tank due to settling. Phosphorus can be naturally treated and removed in soils with the right conditions for removal. Different types of soils remove more phosphorus than others. Removal of phosphorus in soil absorption areas is dependent upon adsorption and precipitation reactions. Precipitation occurs as the phosphorus reacts with calcium, aluminum, magnesium, or iron in the soil. Adsorption is the association of phosphate with the surfaces of a particle. Studies show that phosphate adsorption takes place via formation of a bond between phosphate and a specific site on the adsorbing solid phase (Sposito, 1989). Precipitation involves “the formation of a three-dimensional solid phase arrangement of molecules from the solution phase” (Doner and Grossl, 2002). This is different than adsorption, which involves the formation of a two-dimensional structure (i.e., PO_4^{3-} on the surface of a mineral rather than within the mineral itself). The distinction between these two processes is important because surface adsorption is usually limited by a fixed availability of sorption sites in a particular soil that eventually will be used up if sewage loading occurs over long periods. Precipitation reactions are potentially sustainable provided that there is sustainable supply of aluminum, iron and/or calcium to complete the reaction.

Other Components of Wastewater

Pharmaceuticals

Pharmaceutical and personal care product (PPCP) are of growing concern in wastewater treatment systems. They are chemical substances such as a prescription or over-the-counter therapeutic drugs, fragrances, cosmetics, sunscreen agents, diagnostic agents, among others; widespread use is increasing their prevalence in the environment; their effects, even in trace amounts are being studied.

Other chemicals that are of concern in systems include trace organic contaminants that originate from residential and non-residential sources, such as ingredients in drugs, pesticides, consumer products, and industrial process agents, usually present in concentrations much lower than one mg/L, which may have adverse ecological and/or human health effects.

Chemicals and hazardous waste

Hazardous waste should not be added to a treatment system. Nonhazardous wastes, including detergents, shampoos, antibacterial soap, and salt from water softeners, have not been shown to cause detrimental effects at normal household loading. Excessive loading of any of these chemicals, however, can cause problems with the treatment process.

Of particular concern are continuous toilet cleaners and formaldehyde. Because the toilet flow represents nearly 40 percent of total wastewater, continuous use of a sanitizer can cause problems and should be avoided. Formaldehyde, typically used in chemical toilets, also causes major system problems and should be avoided.

If a residence or any other facility plans to dispose of hazardous waste into an onsite system, the Minnesota Pollution Control Agency (MPCA) must be contacted. These systems would be considered Class V injection wells and are subject to regulations other than those of Chapter 7080. Hair salons, photography businesses and taxidermists, for example, may generate hazardous waste. A Class V inventory form for any such system, as well as for any system serving 20 or more people, must be submitted to the Environmental Protection Agency and the MPCA. A form can be found at septic.umn.edu/ssts-professionals/forms-worksheets.

In the case of filling station wastes, oil, grease and floor washing wastes from the service bay should be discharged to a holding tank separate from the sewage system treating the toilet wastes. Any liquid waste containing petroleum products should not be discharged into a subsurface treatment system. A car wash area should be evaluated for hazardous waste problems, and may also need a holding tank for wastes. There is a potential for volatile compounds in these systems which are capable of being evaporated at relatively low temperatures. These are typically measured as volatile organic compound (VOC) which is the class of organic compounds that readily evaporate; includes liquids and solids at natural environmental temperature.

Monitoring Wastewater Characteristics

Many techniques can be used to monitor an onsite wastewater treatment system's performance. Monitoring is the action of verifying performance for a regulatory authority

or a manufacturer (e.g., qualitative monitoring as part of service visit). It varies from something as simple as checking for sewage on the soil surface, to complicated laboratory analysis. Costs vary from lab to lab. Be sure to contact the lab prior to dropping off samples.

There are several types of samples that can be obtained from a system:

Composite Combination of individual samples collected from the same point at different times; samples may be of equal volume or may be proportional to the flow at time of sampling.

Grab Discrete sample collected at a particular time and location.

Composite Location Discrete sample taken from a location that has a mix of performance values representative of the system performance.

Integrated Combination of grab samples collected at a similar time but at different locations.

Certified Labs

When choosing a lab to perform analysis of wastewater characteristics, a certified lab is always the best choice, because these labs use standard procedures. The Minnesota Department of Health maintains a list of labs across Minnesota that are certified. This can be found on their website at <https://apps.health.state.mn.us/eldo/public/accreditedlabs/labsearch.seam>. If you do not have access to the internet call (800) 383-9808 and a hard copy of the list can be sent to you.

Sampling

There are many locations where samples can be taken. It is best if the sample locations are determined when the system is being designed, and then built in. Effluent chambers, pump tanks and sampling ports are suggested locations at which to obtain samples. A sampling port is a part or device at a particular location in a component that allows a sample to be collected for analysis.

Chapter 7081.0240 (E) requires that MSTs must be designed with sufficient access and ports to monitor the system as applicable.

Some obvious locations where the wastewater characteristics are of interest are:

- as it leaves the home
- as it leaves the pretreatment tank
- at the system's "end-of-pipe"
- in groundwater (lysimeter, sampling wells)
- in soil (dry gram soil/microgram fecal)

Piezometers can be used to determine the amount of separation but are not to be used to sample groundwater. Lysimeters or soil access ports can be used to determine the amount of fecal coliform bacteria under system.

References

- Adolfson Associates, Inc., Burnett Consolidated On-Site Demonstration Project, Final Report, Tacoma-Pierce County Health Department, Washington, 1999.
- Ayres Associates, Florida Keys Onsite Wastewater Nutrient Reduction Systems Demonstration Project, Final Report, Submitted to Florida Department of Health, Onsite Sewage Program, March, 1998.
- Ayres Associates, Onsite Sewage Disposal System Research in Florida, Report Prepared for Environmental Health Program, Department of Health and Rehabilitative Services, State of Florida, March 1993.
- Bohrer, R. M. and Converse, J. C., Soil Treatment Performance and Cold Weather Operation of Drip Distribution Systems, Proceedings of the Ninth National Symposium on Individual and Small Community Sewage Systems, ASAE, Fort Worth, Texas, pp. 561-583, 2001.
- Bouchard, D. C., et al., Nitrate Contamination of Groundwater: Sources and Potential Health Effects, *Journal of AWWA*, Vol. 84, no, 9, pp.85-90, 1992.
- Brooks, M., Alternative On-Site Wastewater Treatment Systems, Department of Civil and Agricultural Engineering, Montana State University, June, 1996.
- California Regional Water Quality Control Board, Evaluation of Alternative Onsite Treatment Systems for the Removal of Nitrogen from Wastewater, Central Coast Region, November 25, 1997.
- CIDWT Decentralized Wastewater Glossary. Available online at: <http://www.onsiteconsortium.org/files/Glossary.pdf> (verified 4/29/2009)
- Converse, M. M., A Field Evaluation of Single Pass Sand filters in a Northern Climate, Master's Thesis, Agricultural Engineering, University of Wisconsin-Madison, 1999.
- County of Butte, Chico Urban Area Nitrate Compliance Plan, Program Report and Proposed Implementation Plan, Butte County Administrative Office, Oroville, California, March, 1998.
- County of Suffolk, Standards for Construction of Modified Sewage Disposal Systems, Department of Health Services, Division of Environmental Quality, Farmingville, New York, March 8, 1989.
- Carducci, A., Tozzi, E., Rubulotta, E., Casini, B., Cantiani, L., Rovini, E., Muscillo, M. and Pacini, R. (2000). Assessing Airborne Biological Hazard from Urban Wastewater Treatment. *Wat. Res.* 34, 4, 1173-1178.
- Centers for Disease Control. (2005). Hepatitis A Fact Sheet. Retrieved August 11, 2008 from <http://hawaii.gov/health/healthy-lifestyles/std-aids/pdfs/hepatitis/hepa-factsheet-CDC.pdf>
- The Center to Protect Workers' Rights. (2004). Biological Hazards in Sewage and Wastewater Treatment Plants. Retrieved August 9, 2008 from http://www.cpwr.com/pdfs/pubs/hazard_alerts/hazsludge.pdf.
- Crites, R., and Tchobanoglous, G., Small and Decentralized Wastewater Management Systems, McGraw-Hill, New York, 1998.
- DeOreo, W.B., Mayer, P., Dziegielewski, B., and J. Kiefer. Residential End Uses of Water,

SECTION 5: Wastewater Sources and Flows ■ 5-65

Version 2. Water Research Foundation. Denver, CO. 2016.

Doner, H.E. and P.R. Grossl (2002). "Carbonates and Evaporites," in Dixon, J.B. and D.G. Schulze, eds., *Soil Mineralogy with Environmental Applications*, Soil Science Society of America, Inc., Madison, WI, p. 207.

Douwes, J., Mannetje, A., Heederik, D. (2001). Work-related Symptoms in Sewage Treatment Workers. *Ann. Agric. Environ. Med.*, 8, 39-45.

Department of Environmental Quality, Nondegradation of Water Quality, Administrative Rules of Montana, Water Quality Division, December 1995.

EPCOR. Okotoks Wastewater Treatment Plant. Retrieved August 9, 2008 from <http://www.epcor.ca/Communities/Alberta/Operations/Water+Treatment+Plants/Okotoks/wtp.htm>.

Frequently Asked Questions & Answers about Wastewater and Biosolids Worker Health & Safety. Retrieved August 9, 2008 from <http://www.biosolids.org/docs/17880.PDF>.

Geerts, S. M., et al., Performance of Pre-engineered Modular Peat Filters for the Treatment of Domestic Wastewater at the Northeast Regional Correction Center, NRRI Technical Report TR-01/35, Natural Resources Research Institute, University of Minnesota – Duluth, November 2001.

Gold, A. J. and Sims, J. T., Research Needs in Decentralized Wastewater Treatment and Management: A Risk-Based Approach to Nutrient Contamination, National Research Needs Conference Proceedings: Risk-Based Decision Making for Onsite Wastewater Treatment, EPRI, US EPA, National Decentralized Water Resources Capacity Development Project 2001.1001446, Palo Alto, CA, 2000.

Gold, A., et al., Wastewater Renovation in Buried and Recirculating Sand Filters, *J. Environmental Quality*, Vol. 21, pp.720-725, 1992.

Gold, A., et al., Nitrogen Removal Systems for On-Site Wastewater Treatment, Proceedings of the 6th Northwest On-Site Wastewater Treatment Short Course, University of Washington, Seattle, September, 1989.

Graydon, J., et al., Onsite Biological Nitrogen Removal Using Recirculating Trickling Filters, In R. E. Hinchey et al., Eds., *Bioremediation of Inorganics*, pp. 133-139, Batelle Press, Columbus, Ohio, 1995.

Hallberg, G. R., Nitrate in Groundwater in the United States, in *Nitrogen Management and Groundwater Protection*, (Edited by R. F. Follett) Elsevier Sci. Publ., Amsterdam, 1989.

Hantzsche, N. and Finnemore, E., Predicting Ground-Water Nitrate-Nitrogen Impacts, *Groundwater*, Vol. 30, No. 4, pp. 490-499, 1992.

Health and Safety Executive. (2004). Working with sewage: The health hazards. Retrieved August 9, 2008 from <http://www.hse.gov.uk/pubns/indg197.pdf>.

Health and Safety Executive. (2004). Working with sewage: The health hazards – A guide for employers. Retrieved August 9, 2008 from <http://www.hse.gov.uk/pubns/indg198>.

Jenkins, D., Hermanowicz, S.W. (1991). Principles of Chemical Phosphorus Removal.

Khuder, Sadik A., Arthur, Tammy, Bisesi, Michael S. and Schaub, Eric A. (1998).

5-66 ■ SECTION 5: Wastewater Sources and Flows

Prevalence of Infectious Diseases and Associated Symptoms in Wastewater Treatment Workers. *American Journal of Industrial Medicine*, 33, 571-577.

Laak, R., *Wastewater Engineering Design for Unsewered Areas*, 2nd Edition, Technomic Publishing, Lancaster, Pennsylvania, 1986.

Laitinen, S., Kangas, J., Kotimaa, M., Liesivuori, J., Martikainen, Pertti J., Nevalainen, A., Sarantila, R., and Husman, Kaj. (1994). Workers' Exposure to Airborne Bacteria and Endotoxins at Industrial Wastewater Treatment Plants. *Am. Ind. Hyg. Assoc.*, 55, 11, 1055-1060.

Leverenz, H., et al., Evaluation of High-Porosity Medium in Intermittently Dosed, Multi-Pass Packed Bed Filters for the Treatment of Wastewater, *Small Flows Quarterly*, Vol. 2, No. 2, pp. 28-35, 2001.

Loomis, G., Department of Natural Resources Science, University of Rhode Island, personal communication, 2002.

Loomis, G. et al., Performance Evaluation of Innovative Treatment Technologies Used to Remediate Failed Septic Systems, *Proceedings of the Ninth National Symposium on Individual and Small Community Sewage Systems*, ASAE, Fort Worth, Texas, pp. 52-61, 2001.

Loudon, T., et al., Cold Climate Performance of Recirculating Sand Filters, *Proceedings of the Fourth National Symposium on Individual and Small Community Sewage Systems*, ASAE, pp. 333-342, 1985.

Magdorf, F.R., D.R. Keeney, J. Bouma, W.A. Ziebell. 1974. Columns representing mound type disposal systems for septic tank effluent: II. nutrient transformations and bacterial populations. *Journal of Environmental Quality*. 3(3) p. 228-234.

Mayer, PW, DeOreo, WB, et al. *Residential End Uses of Water*. American Water Works Association. 1999.

Maloney, J. C., Principal Public Health Engineer, County of Suffolk, Department of Health Services, Farmingville, New York, personal communication, March 7, 1995.

Metcalf & Eddy, *Wastewater Engineering: Treatment, Disposal, and Reuse*, 3rd Edition, McGraw-Hill, New York, 1991.

Miller, Patricia. *Inspections of Onsite Systems Health and Safety*. *Small Flows Quarterly*, 2, 1, 33-36. 2001.

Nolte and Associates, *Literature Review of Recirculating and Intermittent Sand Filter Operation and Performance*, Prepared for the California Regional Water Quality Control Board, Central Valley Region, Redding, California, June, 1992.

Nowak, P., R. Shepard and F. Madison, *Farmers and Manure Management: A Critical Analysis*, In J. L. Hatfield and B. A. Stewart, Eds., *Waste Utilization: Effective Use of Manure as a Soil Resource*, Ann Arbor Press, 1997.

Oakley, S. 2005. *Onsite Nitrogen Removal Text*. in (M.A. Gross and N.E. Deal, eds.) *University Curriculum Development for Decentralized Wastewater Management*. National Decentralized Water Resources Capacity Development Project. University of Arkansas, Fayetteville, AR.

Oakley, S., et al., *Recirculating Trickling Filter Systems for Onsite Nitrogen Removal: Final Report to Butte County*, CSUC Environmental Laboratory, Department of Civil

SECTION 5: Wastewater Sources and Flows ■ 5-67

- Engineering, California State University, Chico, California, May, 1996.
- Oakley, S., et al., Septic Tank and Recirculating Gravel Filter Effluent Treatment and Disposal with Subsurface Absorption Trenches, Final Report for the Town of Paradise, National Demonstration Project for Small Communities, CSUC Environmental Laboratory, Department of Civil Engineering, California State University, Chico, California, September, 1998.
- Oakley, S., et al., Monitoring Nitrogen and Viruses in the Vadose Zone with Suction Lysimeters, Proceedings of the 10th Northwest On-Site Wastewater Treatment Short Course, University of Washington, Seattle, pp. 211-231, September 20-21, 1999.
- Olson, K.; Gustafson, D., Liukkonen, B. and Cook, V. (2005). Septic System Owner's Guide. St. Paul, MN: University of Minnesota Extension Service.
- Pascual, L., Perez-Luz, S., Yanez, M. Adela., Santamaria, A., Gibert, K., Salgot, M., Apraiz, D. and Catalan, V. (2003). Bioaerosol emission from wastewater treatment plants. *Aerobiologia*, 19, 261-270.
- Piluk, R. J. and Peters, E. C., Small Recirculating Sand Filters for Individual Homes, Proceedings 7th International Symposium on Individual and Small Community Sewage Systems, ASAE, Atlanta, 1994.
- Power, J. F. and Schepers, J. S., Nitrate Contamination of Groundwater in North America, Agriculture, Ecosystems, and Environment, Elsevier Sci. Publ., Amsterdam, 1989.
- Prazmo, Z., Krysinska-Traczyk, E., Skorska, C., Sitkowska, J., Cholewa, G. and Dutkiewicz, J. (2003). Exposure to Bioaerosols in a Municipal Sewage Treatment Plant. *Ann. Agric. Environ. Med.*, 10, 241-248.
- Rittmann, B. E. and McCarty, P. L., Environmental Biotechnology: Principles and Applications, McGraw-Hill, New York, 2001.
- Robertson, W. D., and Cherry, J. A., In Situ Denitrification of Septic-System Nitrate Using Reactive Porous Media Barriers: Field Trials, *Groundwater*, Vol. 33, No. 1, pp. 99-111, 1995.
- Ronayne, M. P., et al., Final Report: Oregon On-Site Experimental Systems Program, State of Oregon, Department of Environmental Quality, December 1982.
- Sandy, A. T., et al., Enhanced Nitrogen Removal Using a Modified Recirculating Sand Filter, Proceedings of the Fifth National Symposium on Individual and Small Community Sewage Systems, ASAE, Chicago, pp. 161-170, 1988.
- Sawyer, C., et al., Chemistry for Environmental Engineering, 4th Edition, McGraw-Hill, New York, 1994.
- Sposito, G. (1989). *The Chemistry of Soils*. Oxford University Press.
- Suffolk County, New York, Standards for Approval of Plans and Construction for Sewage Disposal Systems, Appendix A, Standards for Construction of Modified Sewage Disposal Systems, Department of Health Services, Division of Environmental Quality, March 8, 1989.
- US EPA, Manual: Nitrogen Control, EPA/625/R-93/010, Office of Water, Washington, D.C., September, 1993.
- US EPA, Design Manual: Onsite Wastewater Treatment and Disposal Systems, EPA 625/1-80-012, Office of Water Program Operations, Washington, D.C., October 1980.

State of Victoria Department of Education and Early Childhood Development. (2007). Plumbing module: Biological hazards. Retrieved August 9, 2008 from http://www.education.vic.gov.au/safe@work/modules/plumbing/05_biological.asp.

Water Environment Federation, Biological and Chemical Systems for Nutrient Removal, Special Publication, Alexandria, Virginia, 1998.

Water Environment Federation, Natural Systems for Wastewater Treatment, 2nd Edition, Manual of Practice FD-16, Alexandria, Virginia, 2001.

Whitmeyer, R. W., et al., Overview of Individual Onsite Nitrogen Removal Systems, Proceedings of the Sixth National Symposium of Individual and Small Community Sewage Systems, American Society of Agricultural Engineers, ASAE Publication 10-91, pp. 143-154, 1991.

Zimmerman, Bill and Maurer, Hillary. (2007). Mounds and At-Grades the Easy Way. Earthview Environmental LLC. Retrieved August 14, 2008 from http://www.earthviewenvironmental.com/at_grade_mound_constr.pdf

Appendix 1

Biological Hazards in Wastewater: FAQs for Septic System Professionals

Bufford A. Ang; Sara Heger Christopherson; John M. Shutske

Q: *What microorganisms are present in wastewater that can be hazardous to health?*

A: Microorganisms that cause disease are known as pathogens. A variety of pathogens are present in wastewater, including (The Center to Protect Worker's Rights, 2004):

- Bacteria, such as *E. coli*, *Shigella*, *Salmonella*, *Vibrio cholerae*, and *Leptospira*. Bacteria are small, single-celled life-forms that can reproduce quickly. These bacteria can cause diarrhea, fever, cramps, vomiting, headache, weakness, or loss of appetite.
- Parasites. These use other organisms such as humans for food or a place to live and reproduce. One type of parasite is the protozoa. These are single-celled, microscopic organisms that live primarily in water. Some protozoans that cause disease include *Giardia lamblia*, *Cryptosporidium parvum* and Amoeba. Another type of parasite includes helminths, which are worms. Roundworms, for example, can cause ascariasis. A lot of roundworms in your stomach will make you cough, and cause breathing difficulties, abdominal pain, and intestinal blockage.
- Viruses are small particles that infect cells in other organisms. A virus cannot reproduce on its own, but requires other living cells to replicate. Viruses such as Norwalk-like viruses and hepatitis A are passed through feces of infected people. Hepatitis A is the most common virus present in wastewater.

Q: *What are signs of hepatitis A?*

A: One obvious sign of the hepatitis A virus (HAV) is jaundice - yellowing of the skin

or whites of the eyes. Other signs include tiredness, abdominal pain, nausea, and diarrhea. About 15% of people infected with HAV will have prolonged or relapsing symptoms over a 6-9 month period (Centers for Disease Control, 2005).

Q: *What health risks are present in wastewater?*

A: All wastewater will contain fecal coliforms. These bacteria are present in the intestines of all warm-blooded animals, including humans. Although they are important in digestion (and also help with some treatment of wastewater in septic tanks), they may cause varying degrees of illness if introduced to someone through any of the pathways listed later in this paper. Pathogens like *Giardia*, *Cryptosporidia*, *Salmonella*, *Shigella*, *Vibrio cholerae*, etc., will be present only if those using the wastewater treatment system are infected. However, since it is unlikely you will ever know the health conditions of those using a particular system, always assume that health risks exist. Exposure to wastewater may result in a number of illnesses, some of which include (Health & Safety Executive, 2004):

- Gastroenteritis (cramping stomach pains, diarrhea, and vomiting), caused by *E. coli* and other bacteria; protozoans such as *Giardia* and *Cryptosporidia*; and some viruses
- Cholera (extreme diarrhea and dehydration), caused by the bacteria *Vibrio cholerae*
- Leptospirosis (flu-like symptoms, accompanied by a persistent and severe headache), caused by the bacteria *Leptospira*. Leptospirosis may result in damage to liver, kidneys and blood, and may be fatal
- Infectious hepatitis (jaundice and fever) due to the virus Hepatitis A. It causes liver inflammation
- Legionellosis (lung inflammation with fever, dry cough, and aching muscles and joints) caused by a bacteria
- Skin and eye infections

Q: *How can workers come in contact with pathogens?*

A: There are four main routes that explain how pathogens can enter the body. These include (Health & Safety Executive, 2004):

- **Oral** Ingestion via hand-to-mouth contact during eating, drinking, and smoking; and by wiping your face with contaminated hands or gloves. Ingestion is the major route of infection.
- **Dermal** Skin contact from wastewater splashes. Having cuts, scratches, and wounds raises the risk of infection.
- **Eyes** Pathogens can enter the body through the eye.
- **Lungs** Inhaling airborne microbes carried by dust, mist, or fumes.

Q: *What are likely points of microbial contamination?*

A. The following are common sites contaminated with pathogens:

- Air in the vicinity of wastewater can lead to respiratory exposure.
- Tools, vehicle door handles, radio knobs, and gear shifters result in dermal exposure.
- Lunch, cigarettes, gum, etc. can lead to ingestion of pathogens.

5-70 ■ SECTION 5: Wastewater Sources and Flows

Q: *Where are pathogens found in wastewater treatment systems?*

A: Pathogens are present in wastewater, and can be found anywhere and on anything that is in contact with wastewater. This means they will be found in the septic tank, distribution pipes, and effluent treatment components such as a drainfield, mound, recirculating sand filter, etc. Highest populations are present in the septic tank, and are reduced as wastewater receives treatment while traveling through the system (see image below). In properly designed, installed, and maintained systems, research has shown there are no pathogens found in wastewater once it has traveled through soil three feet below the bottom of the drainfield (Zimmerman and Maurer, 2007). Please see table on the following page.

TABLE A-1 Numbers of pathogens found in wastewater at various stages of treatment in an onsite system (Zimmerman and Maurer, 2007)

Microorganism	Raw wastewater	Septic tank effluent	1 ft below trench	3 ft below trench
Fecal coliforms (MPN/100 ml)	1,000,000 – 100,000,000	1,000 – 1,000,000,000	0 - 100	0
Viruses (CFU/ml)	unknown	1,000 – 1,000,000,000	0 - 1000	0

In wastewater treatment plants, pathogens have been found in the following components and processes:

- Pre-treatment
- Thickening, dewatering, primary and secondary sludge treatment
- Primary clarifiers and settlers
- Aeration (biological oxidation) tank
- Sludge processing unit
- Belt press machines (belt press area)
- Sludge collection hoppers
- Sludge dewatering area
- Incoming water tunnels
- Inflow chambers
- Aerated basins with sprinkler systems
- Trickling filters
- Grit collection
- Biofilter tower interior
- Servicing and cleaning equipment
- Washing stations

Q: *What can septic system workers and wastewater treatment plant employees do to protect themselves from pathogens?*

A: Since pathogens are naturally found in wastewater, they CANNOT be removed. The risk of contracting a disease decreases if you practice good personal hygiene and use personal protective equipment on the job. Some pointers to keep in mind and to practice are:

SECTION 5: Wastewater Sources and Flows ▪ 5-71

- Make sure you understand the risks these microbes pose to your health, and ways that you can pick up infections.
- Always have a first aid kit handy. Clean and disinfect all exposed wounds, and cover with a sterile waterproof dressing.
- Report any injuries suffered at the work site to your supervisor right away.
- Use waterless hand cleaners, anti-bacterial soaps, and anti-bacterial hand wipes on the job.
- DO NOT eat or drink in a wastewater handling area.
- Do not touch your nose, mouth, eyes, or ears with your hands unless you have just washed your hands.
- Wash your hands well with soap and clean hot water before you eat or smoke, periodically throughout the day, and at the end of your workday. Assume anything coming in contact with wastewater is contaminated!
- Clean any part of you that comes in contact with wastewater or sludge immediately.
- Keep your fingernails short and clean them frequently.
- Wear waterproof gloves when cleaning pumps or screens, or when handling wastewater, sludge, or grit. Whenever possible, wear heavy-duty gloves (double glove) and boots that are waterproof and puncture resistant (The Center to Protect Worker's Rights, 2004).
- Wear a surgical-type mask, goggle, face shield, or visor if there is a chance that you will be splashed with wastewater.
- Wear rubber boots or those that can be disinfected if you should step in wastewater.
- Report any damaged equipment right away for replacement or repair.
- Handle sharp items with extra care to prevent accidental injuries.
- Clean contaminated equipment/tools on site with a bleach solution (Miller, 2001) (1 tablespoon of bleach to 1 gallon of water). Bleach loses its effectiveness after exposure to sunlight or dirt, so keep a fresh supply handy.
- Shower and change your work clothes before leaving work for the day. Do not take contaminated clothing home for washing. Use two different lockers to separate your work and street clothes. If you must launder your clothing at home, launder your work clothing separately from family clothing.
- Wash work clothing in hot water with chlorine bleach.
- Discuss your occupation with your health care providers so they know what potential exposures you have due to your work.
- Be sure your vaccine shots are up-to-date, especially for tetanus and diphtheria. Vaccination against hepatitis A is highly recommended.
- Consult your healthcare provider for any flu-like symptoms, such as fever or severe headache, or any skin infections. Seek medical help if chest symptoms consistent with asthma appear.

Q: *So, do professionals really need to worry about airborne droplets and dust that carry pathogens (bioaerosols)?*

A: Yes! In 2003, Prazmo and her colleagues studied Polish sewer workers who were exposed to droplet aerosols containing infectious biological agents. These aerosols impaired the immune system and had the potential to produce allergies in susceptible individuals. Prazmo and her colleagues listed the infectious agents present, which included viruses (polioviruses, coxsackieviruses, echoviruses, rotaviruses, adenoviruses, Norwalk virus), and bacteria (*Leptospira*, *Salmonella* spp., *Shigella* spp., *Campylobacter jejuni*, *Yersinia enterocolitica*, *Legionella pneumophila*, *Helicobacter pylori*, *Listeria monocytogenes*, *Mycobacterium xenopi*). Another risk that they cited was microbial allergens and endotoxins. They stated that endotoxins, produced by bacteria, can cause respiratory and intestinal inflammation, diarrhea, fatigue, and nose irritation among sewer workers.

Q: *When, what type, and how should a professional wear a respirator?*

A: A respirator should be worn whenever you might come in contact with airborne pathogens, such as spray from a treatment device, or a humid atmosphere. The N-95 Respirator is recommended by the National Institute for Occupational Safety and Health (NIOSH). Fit of respirator is always important to make sure that there is a tight seal between the face and mask. A leak would result in the inhalation of contaminated air. Facial hair is discouraged, since this can interfere with proper respirator fit. To make sure respirators are fitted, worn, and used properly, a respiratory protection program for the facility is highly recommended.

Q: *Just what is the level of risk for an ordinary individual to get exposed to pathogens in wastewater?*

A. The answer is “It depends.” The risk for an ordinary individual getting exposed to pathogens depends upon how well the septic system was designed, installed, and maintained. If there is wastewater draining to or surfacing in the yard, there is greater risk than if the system is working properly. If the septic system was installed in an area with high groundwater levels, and/or close to a drinking water well, the risk is higher. If a homeowner maintains his/her own system and cleans the effluent screen, the risk is higher for that person than if a professional is hired. However, if that homeowner follows safety precautions, the risk will be reduced.

All in all, if a system is designed considering the strength and volume of wastewater, the soil and site specifics; installed using best management practices; and maintained properly, risk to an ordinary individual is minimal.